



April 30, 2018

CERTIFIED: 7008 2810 0002 1315 1036

Department of Environmental Quality
Office of Environmental Compliance
Enforcement Division
P.O. Box 4312
Baton Rouge, LA 70821-4312

Re: NSPS Excess Emissions & CEM Performance Report – 1st Quarter 2018
Valero Refining - Meraux LLC, Agency Interest # 1238
22235 Jacob Drive., St. Bernard Parish, Meraux, LA
Title V Permit Numbers: 2500-00001-V16

Gentlemen,

Valero Refining, Meraux LLC is submitting this Excess Emissions and Monitoring Systems Reports, per LAC 33:III, Chapter 30, 40 CFR 60.7(c), 40 CFR 60.108a(d) and 40 CFR 63.1575 for the First Quarter 2018.

For this reporting period, the #2 SRU (EPN 1-93, EQT 0019) and the #3 SRU (EPN 5-00, EQT 0079) had excess emissions greater than 1% of the total operating time and no CEMS had downtime greater than 5% of the total operating time.

Enclosed are the Data Assessment Reports for the appropriate CEMs and information required by NSPS Subpart Ja, 40 CFR 60.108a(d). Subpart Ja root cause and corrective action analysis reports are included with this submittal. Updates to previously submitted Subpart Ja root cause and corrective action analysis reports are also included if corrective actions were completed in this reporting period.

Should you have any questions regarding this submission, please contact Mr. Justin Stubbe at (504) 271-4141.

I certify, based on information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete.

Regards,

A handwritten signature in dark ink, appearing to read 'Mike Dehart', followed by the text 'for Jack Merrill'.

Mike Dehart
Director Refinery Operations
Valero Refining – Meraux LLC

Enclosures

cc: Mr. Brian Tusa, LDEQ SE Regional Office, New Orleans, LA

SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSIONS AND MONITORING SYSTEMS PERFORMANCE

(per 40 CFR 60.7(d) and 60.108a(d))

Pollutant: **SO₂**

Applicable NSPS Subpart: Ja

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: SO₂ corrected to 0% O₂ shall not exceed 250 ppm on a 12-hour rolling average

Monitor Manufacturer and Model No.: Brimstone SGX-231(SO₂)/Rosemount Oxymitter 4000(O₂)

Date of Latest CMS Certification or Audit: CGA on 1/16/18

Process Unit(s) Description: #2 SRU Incinerator (EPN 1-93, EQT 0019)

Total source operating time in reporting period: 2,046 hours

Emissions Data Summary¹	
1. Duration of excess emissions in reporting period due to:	<i>(hours)</i>
a. Startup/shutdown	66
b. Control equipment problems	0
c. Process problems	12
d. Other known causes	0
e. Unknown causes	0
2. Total duration of excess emission	78
3. Total duration of excess emissions x (100) [Total source operating time] ²	3.8 %

CMS Performance Summary¹	
1. CMS downtime in reporting period due to:	<i>(hours)</i>
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	1
3. Total duration of CMS Downtime x (100) [Total source operating time] ²	0.0 %

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in §60.7(c) shall be submitted.

SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSIONS AND MONITORING SYSTEMS PERFORMANCE

(per 40 CFR 60.7(d) and 60.108a(d))

Pollutant: **SO₂**

Applicable NSPS Subpart: Ja

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: SO₂ corrected to 0% O₂ shall not exceed 250 ppm on a 12-hour rolling average.

Monitor Manufacturer and Model No.: ABB AO2000 Uras 26(SO₂)/ Magnos 206 (O₂)

Date of Latest CMS Certification or Audit: CGA on 1/10/18

Process Unit(s) Description: #3 SRU Incinerator (EPN 5-00, EQT 0079)

Total source operating time in reporting period: 2,080 hours

Emissions Data Summary¹	
1. Duration of excess emissions in reporting period due to:	<i>(hours)</i>
a. Startup/shutdown	42
b. Control equipment problems	0
c. Process problems	45
d. Other known causes	0
e. Unknown causes	0
2. Total duration of excess emission	87
3. Total duration of excess emissions x (100) [Total source operating time] ²	4.2 %

CMS Performance Summary¹	
1. CMS downtime in reporting period due to:	<i>(hours)</i>
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	1
3. Total duration of CMS Downtime x (100) [Total source operating time] ²	0.0 %

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in §60.7(c) shall be submitted.

**SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSIONS AND
MONITORING SYSTEMS PERFORMANCE**

(per 40 CFR 60.7(d))

Pollutant: **H₂S**

Applicable NSPS Subpart: J

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Hydrogen Sulfide shall not exceed 162 ppm on a 3-hour rolling average

Monitor Manufacturer and Model No.: Ametek, #4661

Date of Latest CMS Certification or Audit: CGA on 1/12/18

Process Unit(s) Description: Area 1 Fuel Drum for Boiler TB-01 (EPN 1-06, EQT 0010), Boiler B-7 (EPN 1-07, EQT 0011), MDH
Product and Fractionator Heaters (EPN 2-92, EQT 0033)

Total source operating time in reporting period: EQT 0010- 2,038 hours, EQT 0011- 1,583 hours, EQT 0033- 1,886 hours

Emissions Data Summary¹			
1. Duration of excess emissions in reporting period due to:	<i>EQT 0010</i> (hours)	<i>EQT 0011</i> (hours)	<i>EQT 0033</i> (hours)
a. Startup/shutdown	0	0	0
b. Control equipment problems	0	0	0
c. Process problems	0	0	0
d. Other known causes	0	0	0
e. Unknown causes	0	0	0
2. Total duration of excess emission	0	0	0
3. Total duration of excess emissions x (100) [Total source operating time] ²	0.0 %	0.0 %	0.0 %

CMS Performance Summary¹			
1. CMS downtime in reporting period due to:	<i>EQT 0010</i> (hours)	<i>EQT 0011</i> (hours)	<i>EQT 0033</i> (hours)
a. Monitor equipment malfunctions	0	0	0
b. Non-Monitor equipment malfunctions	0	0	0
c. Quality assurance calibration	0	0	0
d. Other known causes	0	0	0
e. Unknown causes	0	0	0
2. Total CMS Downtime	0	0	0
3. Total duration of CMS Downtime x (100) [Total source operating time] ²	0.0 %	0.0 %	0.0 %

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in §60.7(c) shall be submitted. (Percentage based on the lowest operating time.)

SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSIONS AND MONITORING SYSTEMS PERFORMANCE

(per 40 CFR 60.7(d))

Pollutant: **H₂S**

Applicable NSPS Subpart: J

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Subpart J: Hydrogen Sulfide shall not exceed 162 ppm on a 3-hour rolling average.

Monitor Manufacturer and Model No.: Ametek 4661

Date of Latest CMS Certification or Audit: CGA on 1/26/18

Process Unit(s) Description: Area 2 Fuel Drum for: Vacuum Heater (EPN 1-76, EQT 0013); No.1 Crude Heater (EPN 12-72A, EQT 0022); NHT Charge Heater (EPN 14-72, EQT 0023); NHT Debut Reboiler (EPN 15-72, EQT 0024); NHT Depent Reboiler (EPN 16-72 EQT 0027); Platformer Charge Heater (EPN 17-72 a,b,c , EQT 0028); Platformer Debut Reboiler (EPN 19-72, EQT 0029); DHT Charge Heater (EPN 5-73, EQT 0058); ROSE Heater (EPN 1-80, EQT 0014)

Total source operating time in reporting period: EQT 0013-1,870 hours; EQT 0022-1,907 hours; EQT 0023-1,771 hours; EQT 0024-1,761 hours; EQT 0027-1,757 hours; EQT 0028-1,769 hours; EQT 0029-1,659 hours; EQT 0058-766 hours; EQT 0014 - 2,084 hours

Emissions Data Summary¹	
1. Duration of excess emissions in reporting period due to:	<i>All EQT's (hours)</i>
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	2
d. Other known causes	0
e. Unknown causes	0
2. Total duration of excess emission	2
3. Total duration of excess emissions x (100) [Total source operating time] ²	0.1 %

CMS Performance Summary¹	
1. CMS downtime in reporting period due to:	<i>All EQT's (hours)</i>
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	0
3. Total duration of CMS Downtime x (100) [Total source operating time] ²	0.0 %

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in §60.7(c) shall be submitted.

SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSIONS AND MONITORING SYSTEMS PERFORMANCE

(per 40 CFR 60.7(d) and 60.108a(d))

Pollutant: **H₂S**

Applicable NSPS Subpart: Ja

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Subpart Ja: Hydrogen Sulfide shall not exceed 162 ppm on a 3-hour rolling average and 60 ppm on a 365 day rolling average.

Monitor Manufacturer and Model No.: Ametek 4661

Date of Latest CMS Certification or Audit: CGA on 1/26/18

Process Unit(s) Description: Area 2 Fuel Drum for Benzene Recovery Unit Reboiler (EPN 1-09, EQT 0127)

Total source operating time in reporting period: 1,704 hours

Emissions Data Summary¹	
1. Duration of excess emissions in reporting period due to:	<i>(hours)</i>
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	2
d. Other known causes	0
e. Unknown causes	0
2. Total duration of excess emission	2
3. Total duration of excess emissions x (100) [Total source operating time] ²	0.1 %

CMS Performance Summary¹	
1. CMS downtime in reporting period due to:	<i>(hours)</i>
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	0
3. Total duration of CMS Downtime x (100) [Total source operating time] ²	0.0 %

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in §60.7(c) shall be submitted.

**SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSIONS AND
MONITORING SYSTEMS PERFORMANCE**

(per 40 CFR 60.7(d))

Pollutant: **H₂S**

Applicable NSPS Subpart: J

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Hydrogen Sulfide shall not exceed 162 ppm on a 3-hour rolling average.

Monitor Manufacturer and Model No.: Ametek 4661

Date of Latest CMS Certification or Audit: CGA on 1/26/18

Process Unit(s) Description: Area 4 Fuel Drum for Merox Disulfide Separator to Platformer Charge Heater

Total source operating time in reporting period: 1,727 hours

Emissions Data Summary¹	
1. Duration of excess emissions in reporting period due to:	<i>(hours)</i>
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	2
d. Other known causes	0
e. Unknown causes	0
2. Total duration of excess emission	2
3. Total duration of excess emissions x (100) [Total source operating time] ²	0.1 %

CMS Performance Summary¹	
1. CMS downtime in reporting period due to:	<i>(hours)</i>
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	15
e. Unknown causes	0
2. Total CMS Downtime	15
3. Total duration of CMS Downtime x (100) [Total source operating time] ²	0.9 %

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in §60.7(c) shall be submitted.

SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSIONS AND MONITORING SYSTEMS PERFORMANCE

(per 40 CFR 60.7(d))

Pollutant: **H₂S**

Applicable NSPS Subpart: J

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Hydrogen Sulfide shall not exceed 162 ppm on a 3-hour rolling average.

Monitor Manufacturer and Model No.: Ametek 4661

Date of Latest CMS Certification or Audit: CGA on 1/12/18

Process Unit(s) Description: Area 6 Fuel Drum for Hydrocracker & Hydrotreater Charge Heaters (EPN 1-00, EQT 0009)

Total source operating time in reporting period: 1,936 hours

Emissions Data Summary¹	
1. Duration of excess emissions in reporting period due to:	<i>(hours)</i>
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	2
d. Other known causes	0
e. Unknown causes	0
2. Total duration of excess emission	2
3. Total duration of excess emissions x (100) [Total source operating time] ²	0.1 %

CMS Performance Summary¹	
1. CMS downtime in reporting period due to:	<i>(hours)</i>
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	1
3. Total duration of CMS Downtime x (100) [Total source operating time] ²	0.1 %

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in §60.7(c) shall be submitted.

**SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSIONS AND
MONITORING SYSTEMS PERFORMANCE**

(per 40 CFR 60.7(d))

Pollutant: **H₂S**

Applicable NSPS Subpart: J

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Hydrogen Sulfide shall not exceed 162 ppm on a 3-hour rolling average.

Monitor Manufacturer and Model No.: Ametek 4661

Date of Latest CMS Certification or Audit: CGA on 1/26/18

Process Unit(s) Description: Area 6 Fuel Drum for Boiler B-5 (EPN 2-00, EQT 0030) and Boiler B-6 (EPN 3-00, EQT 0048)

Total source operating time in reporting period: EQT 0030-2,054 hours; EQT 0048-0 hours³

Emissions Data Summary¹		
1. Duration of excess emissions in reporting period due to:	<i>EQT 0030 (hours)</i>	<i>EQT 0048 (hours)</i>
a. Startup/shutdown	0	0
b. Control equipment problems	0	0
c. Process problems	3	0
d. Other known causes	0	0
e. Unknown causes	0	0
2. Total duration of excess emission	3	0
3. Total duration of excess emissions x (100) [Total source operating time] ²	0.1 %	0.0 %

CMS Performance Summary¹		
1. CMS downtime in reporting period due to:	<i>EQT 0030 (hours)</i>	<i>EQT 0048 (hours)</i>
a. Monitor equipment malfunctions	0	0
b. Non-Monitor equipment malfunctions	0	0
c. Quality assurance calibration	1	0
d. Other known causes	0	0
e. Unknown causes	0	0
2. Total CMS Downtime	1	0
3. Total duration of CMS Downtime x (100) [Total source operating time] ²	0.0 %	0.0 %

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in §60.7(c) shall be submitted.

³ Boiler B-6 ran on purchased natural gas for the entire Quarter.

SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSIONS AND MONITORING SYSTEMS PERFORMANCE

(per 40 CFR 60.7(d))

Pollutant: **NO_x**

Applicable NSPS Subpart: Db

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Nitrogen Oxide shall not exceed 0.1 pound/MMBtu on a 30-day rolling average.

Monitor Manufacturer and Model No.: ABB Limas11(NOx), Magnos27 (O₂)

Date of Latest CMS Certification or Audit: CGA on 1/23/18

Process Unit(s) Description: Boiler B-5 (EPN 2-00, EQT 0030)

Total source operating time in reporting period: 2,052 hours

Emissions Data Summary¹	
1. Duration of excess emissions in reporting period due to:	<i>(hours)</i>
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total duration of excess emission	0
3. Total duration of excess emissions x (100) [Total source operating time] ²	0.0 %

CMS Performance Summary¹	
1. CMS downtime in reporting period due to:	<i>(hours)</i>
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	4
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	4
3. Total duration of CMS Downtime x (100) [Total source operating time] ²	0.2 %

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in §60.7(c) shall be submitted.

**SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSIONS AND
MONITORING SYSTEMS PERFORMANCE**

(per 40 CFR 60.7(d))

Pollutant: **NO_x**

Applicable NSPS Subpart: Db

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Nitrogen Oxide shall not exceed 0.1 pound/MMBtu on a 30-day rolling average.

Monitor Manufacturer and Model No.: ABB Limas11(NOx), Magnos27 (O₂)

Date of Latest CMS Certification or Audit: CGA on 1/23/18

Process Unit(s) Description: Boiler B-6 (EPN 3-00, EQT 0048)

Total source operating time in reporting period: 2,066 hours

Emissions Data Summary¹	
1. Duration of excess emissions in reporting period due to:	<i>(hours)</i>
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total duration of excess emission	0
3. Total duration of excess emissions x (100) [Total source operating time] ²	0.0 %

CMS Performance Summary¹	
1. CMS downtime in reporting period due to:	<i>(hours)</i>
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	4
e. Unknown causes	0
2. Total CMS Downtime	4
3. Total duration of CMS Downtime x (100) [Total source operating time] ²	0.2 %

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in §60.7(c) shall be submitted.

SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSIONS AND MONITORING SYSTEMS PERFORMANCE

(per 40 CFR 60.7(d))

Pollutant: **NO_x**

Applicable NSPS Subpart: Db

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Nitrogen Oxide shall not exceed 0.1 pound/MMBtu on a 30-day rolling average.

Monitor Manufacturer and Model No.: Thermo Environmental 42i (NO_x)/(O₂)

Date of Latest CMS Certification or Audit: CGA on 1/25/18

Process Unit(s) Description: Boiler TB-01 (EPN 1-06, EQT 0010)

Total source operating time in reporting period: 2,038 hours

Emissions Data Summary¹	
1. Duration of excess emissions in reporting period due to:	<i>(hours)</i>
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total duration of excess emission	0
3. Total duration of excess emissions x (100) [Total source operating time] ²	0.0 %

CMS Performance Summary¹	
1. CMS downtime in reporting period due to:	<i>(hours)</i>
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	3
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	3
3. Total duration of CMS Downtime x (100) [Total source operating time] ²	0.1 %

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in §60.7(c) shall be submitted.

SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSIONS AND MONITORING SYSTEMS PERFORMANCE

(per 40 CFR 60.7(d) and 60.108a(d))

Pollutant: **NO_x**

Applicable NSPS Subpart: Ja

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Nitrogen Oxide corrected to 0% O₂ shall not exceed 40 ppm on a 30-day rolling average

Monitor Manufacturer and Model No.: Thermo Environmental 42i (NO_x)/(O₂)

Date of Latest CMS Certification or Audit: CGA on 1/14/18

Process Unit(s) Description: Benzene Recovery Unit Reboiler (EPN 1-09, EQT 0127)

Total source operating time in reporting period: 1,704 hours

Emissions Data Summary¹	
1. Duration of excess emissions in reporting period due to:	<i>(hours)</i>
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total duration of excess emission	0
3. Total duration of excess emissions x (100) [Total source operating time] ²	0.0 %

CMS Performance Summary¹	
1. CMS downtime in reporting period due to:	<i>(hours)</i>
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	1
3. Total duration of CMS Downtime x (100) [Total source operating time] ²	0.1 %

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in §60.7(c) shall be submitted.

SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSIONS AND MONITORING SYSTEMS PERFORMANCE

(per 40 CFR 60.7(d) and 60.108a(d))

Pollutant: **NO_x**

Applicable NSPS Subpart: N/A (Required by Consent Decree: 3:10-cv-00563-bbc, Paragraph 36.a)

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: None

Monitor Manufacturer and Model No.: ABB Limas11(NOx), Magnos27 (O₂)

Date of Latest CMS Certification or Audit: CGA on 1/28/18

Process Unit(s) Description: No.1 Crude Heater (EPN 12-72A, EQT 0022)

Total source operating time in reporting period: 1,907 hours

Emissions Data Summary¹	
1. Duration of excess emissions in reporting period due to:	<i>(hours)</i>
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total duration of excess emission	0
3. Total duration of excess emissions x (100) [Total source operating time] ²	0.0 %

CMS Performance Summary¹	
1. CMS downtime in reporting period due to:	<i>(hours)</i>
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	1
3. Total duration of CMS Downtime x (100) [Total source operating time] ²	0.1 %

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in §60.7(c) shall be submitted.

SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSIONS AND MONITORING SYSTEMS PERFORMANCE

(per 40 CFR 60.7(d) and 60.108a(d))

Pollutant: **H₂S**

Applicable NSPS Subpart: Ja

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Hydrogen Sulfide shall not exceed 162 ppm on a 3-hour rolling average.

Monitor Manufacturer and Model No.: Ametek 5100

Date of Latest CMS Certification or Audit: CGA on 1/11/18

Process Unit(s) Description: North Flare Stack (EPN 20-72, EQT 0035), North Flare Header

Total source operating time in reporting period: 2,159 hours

Emissions Data Summary¹	
1. Duration of excess emissions in reporting period due to:	<i>(hours)</i>
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	17
e. Unknown causes	0
2. Total duration of excess emission	17
3. Total duration of excess emissions x (100) [Total source operating time] ²	0.8 %

CMS Performance Summary¹	
1. CMS downtime in reporting period due to:	<i>(hours)</i>
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	0
3. Total duration of CMS Downtime x (100) [Total source operating time] ²	0.0 %

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in §60.7(c) shall be submitted.

SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSIONS AND MONITORING SYSTEMS PERFORMANCE

(per 40 CFR 60.7(d) and 60.108a(d))

Pollutant: **H₂S**

Applicable NSPS Subpart: Ja

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Hydrogen Sulfide shall not exceed 162 ppm on a 3-hour rolling average.

Monitor Manufacturer and Model No.: Ametek 5100

Date of Latest CMS Certification or Audit: CGA on 1/10/18

Process Unit(s) Description: North Flare Stack (EPN 20-72, EQT 0035), Hydrocracker Flare Header

Total source operating time in reporting period: 2,159 hours

Emissions Data Summary¹	
1. Duration of excess emissions in reporting period due to:	<i>(hours)</i>
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	17
e. Unknown causes	0
2. Total duration of excess emission	17
3. Total duration of excess emissions x (100) [Total source operating time] ²	1.0 %

CMS Performance Summary¹	
1. CMS downtime in reporting period due to:	<i>(hours)</i>
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	0
3. Total duration of CMS Downtime x (100) [Total source operating time] ²	0.0 %

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in §60.7(c) shall be submitted.

**SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSIONS AND
MONITORING SYSTEMS PERFORMANCE**

(per 40 CFR 60.7(d) and 60.108a(d))

Pollutant: **H₂S**

Applicable NSPS Subpart: Ja

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Hydrogen Sulfide shall not exceed 162 ppm on a 3-hour rolling average.

Monitor Manufacturer and Model No.: Ametek 5100

Date of Latest CMS Certification or Audit: CGA on 1/12/18

Process Unit(s) Description: South Flare Stack (EPN 3-77, EQT 0049)

Total source operating time in reporting period: 2,159 hours

Emissions Data Summary¹	
1. Duration of excess emissions in reporting period due to:	<i>(hours)</i>
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	12
e. Unknown causes	0
2. Total duration of excess emission	12
3. Total duration of excess emissions x (100) [Total source operating time] ²	0.0 %

CMS Performance Summary¹	
1. CMS downtime in reporting period due to:	<i>(hours)</i>
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	0
3. Total duration of CMS Downtime x (100) [Total source operating time] ²	0.0 %

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in §60.7(c) shall be submitted.

SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSIONS AND MONITORING SYSTEMS PERFORMANCE

(per 40 CFR 60.7(d) and 60.108a(d))

Pollutant: **Total Sulfur**

Applicable NSPS Subpart: Ja (Also Required by Consent Decree: 3:10-cv-00563-bbc, Paragraph 49.a.ii)

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: None

Monitor Manufacturer and Model No.: Thermo Scientific SOLA II

Date of Latest CMS Certification or Audit: CGA on 1/12/18

Process Unit(s) Description: North Flare Stack (EPN 20-72, EQT 0035), North Flare Header

Total source operating time in reporting period: 2,159 hours

Emissions Data Summary¹	
1. Duration of excess emissions in reporting period due to:	<i>(hours)</i>
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total duration of excess emission	0
3. Total duration of excess emissions x (100) [Total source operating time] ²	0.0 %

CMS Performance Summary¹	
1. CMS downtime in reporting period due to:	<i>(hours)</i>
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	5
d. Other known causes	20
e. Unknown causes	0
2. Total CMS Downtime	25
3. Total duration of CMS Downtime x (100) [Total source operating time] ²	1.2 %

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in §60.7(c) shall be submitted.

SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSIONS AND MONITORING SYSTEMS PERFORMANCE

(per 40 CFR 60.7(d) and 60.108a(d))

Pollutant: **Total Sulfur**

Applicable NSPS Subpart: Ja (Also Required by Consent Decree: 3:10-cv-00563-bbc, Paragraph 49.a.ii)

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: None

Monitor Manufacturer and Model No.: Thermo Scientific SOLA II

Date of Latest CMS Certification or Audit: CGA on 1/12/18

Process Unit(s) Description: North Flare Stack (EPN 20-72, EQT 0035), Hydrocracker Flare Header

Total source operating time in reporting period: 2,159 hours

Emissions Data Summary¹	
1. Duration of excess emissions in reporting period due to:	<i>(hours)</i>
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total duration of excess emission	0
3. Total duration of excess emissions x (100) [Total source operating time] ²	0.0 %

CMS Performance Summary¹	
1. CMS downtime in reporting period due to:	<i>(hours)</i>
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	2
d. Other known causes	19
e. Unknown causes	0
2. Total CMS Downtime	21
3. Total duration of CMS Downtime x (100) [Total source operating time] ²	1.0 %

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in §60.7(c) shall be submitted.

SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSIONS AND MONITORING SYSTEMS PERFORMANCE

(per 40 CFR 60.7(d) and 60.108a(d))

Pollutant: **Total Sulfur**

Applicable NSPS Subpart: Ja (Also Required by Consent Decree: 3:10-cv-00563-bbc, Paragraph 49.a.ii)

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: None

Monitor Manufacturer and Model No.: Thermo Scientific SOLA II

Date of Latest CMS Certification or Audit: CGA on 1/27/18

Process Unit(s) Description: South Flare Stack (EPN 3-77, EQT 0049)

Total source operating time in reporting period: 2,159 hours

Emissions Data Summary¹	
1. Duration of excess emissions in reporting period due to:	<i>(hours)</i>
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total duration of excess emission	0
3. Total duration of excess emissions x (100) [Total source operating time] ²	0.0 %

CMS Performance Summary¹	
1. CMS downtime in reporting period due to:	<i>(hours)</i>
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	5
d. Other known causes	18
e. Unknown causes	0
2. Total CMS Downtime	23
3. Total duration of CMS Downtime x (100) [Total source operating time] ²	1.1 %

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in §60.7(c) shall be submitted.

SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSIONS AND MONITORING SYSTEMS PERFORMANCE

(per 40 CFR 60.7(d) and 60.108a(d))

Pollutant: **Flow**

Applicable NSPS Subpart: Ja (Also Required by Consent Decree: 3:10-cv-00563-bbc, Paragraph 49.a.ii)

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: None

Monitor Manufacturer and Model No.: GE Panametrics GF 868

Date of Latest CMS Certification or Audit: N/A

Process Unit(s) Description: North Flare Stack (EPN 20-72, EQT 0035), North Flare Header

Total source operating time in reporting period: 2,159 hours

Emissions Data Summary¹	
1. Duration of excess emissions in reporting period due to:	<i>(hours)</i>
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total duration of excess emission	0
3. Total duration of excess emissions x (100) [Total source operating time] ²	0.0 %

CMS Performance Summary¹	
1. CMS downtime in reporting period due to:	<i>(hours)</i>
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	20
e. Unknown causes	0
2. Total CMS Downtime	20
3. Total duration of CMS Downtime x (100) [Total source operating time] ²	0.9 %

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in §60.7(c) shall be submitted.

**SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSIONS AND
MONITORING SYSTEMS PERFORMANCE**

(per 40 CFR 60.7(d) and 60.108a(d))

Pollutant: **Flow**

Applicable NSPS Subpart: Ja (Also Required by Consent Decree: 3:10-cv-00563-bbc, Paragraph 49.a.ii)

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: None

Monitor Manufacturer and Model No.: GE Panametrics GF 868

Date of Latest CMS Certification or Audit: N/A

Process Unit(s) Description: North Flare Stack (EPN 20-72, EQT 0035), Hydrocracker Flare Header

Total source operating time in reporting period: 2,159 hours

Emissions Data Summary¹	
1. Duration of excess emissions in reporting period due to:	<i>(hours)</i>
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total duration of excess emission	0
3. Total duration of excess emissions x (100) [Total source operating time] ²	0.0 %

CMS Performance Summary¹	
1. CMS downtime in reporting period due to:	<i>(hours)</i>
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	11
e. Unknown causes	0
2. Total CMS Downtime	11
3. Total duration of CMS Downtime x (100) [Total source operating time] ²	0.5 %

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in §60.7(c) shall be submitted.

SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSIONS AND MONITORING SYSTEMS PERFORMANCE

(per 40 CFR 60.7(d) and 60.108a(d))

Pollutant: **Flow**

Applicable NSPS Subpart: Ja (Also Required by Consent Decree: 3:10-cv-00563-bbc, Paragraph 49.a.ii)

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: None

Monitor Manufacturer and Model No.: GE Panametrics GF 868

Date of Latest CMS Certification or Audit: N/A

Process Unit(s) Description: South Flare Stack (EPN 3-77, EQT 0049)

Total source operating time in reporting period: 2,159 hours

Emissions Data Summary¹	
1. Duration of excess emissions in reporting period due to:	<i>(hours)</i>
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total duration of excess emission	0
3. Total duration of excess emissions x (100) [Total source operating time] ²	0.0 %

CMS Performance Summary¹	
1. CMS downtime in reporting period due to:	<i>(hours)</i>
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	20
e. Unknown causes	0
2. Total CMS Downtime	20
3. Total duration of CMS Downtime x (100) [Total source operating time] ²	0.9 %

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in §60.7(c) shall be submitted.

**GASEOUS AND OPACITY EXCESS EMISSIONS AND
MONITORING SYSTEMS PERFORMANCE**

(per 40 CFR 60.7(c) and 60.108a(d))

Pollutant: **SO₂**

Applicable NSPS Subpart: Ja

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: SO₂ corrected to 0% O₂ shall not exceed 250 ppm on a 12-hour rolling average

Monitor Manufacturer and Model No.: Brimstone SGX-231(SO₂)/Rosemount Oxymitter 4000(O₂)

Date of Latest CMS Certification or Audit: CGA on 1/16/18

Process Unit(s) Description: #2 SRU Incinerator (EPN 1-93, EQT 0019)

Total source operating time in reporting period: 2,046 hours

Ja EXCESS EMISSIONS						
Date	Start	End	Duration (hours)	Max 12-HRA (ppm)	Cause	Corrective Action
1/21/18	14:00		66	786	SO ₂ at 0% O ₂ greater than 250 ppm, 12-HRA, with SO ₂ emissions greater than 500 lbs/day above the allowable limit while operating in hot standby following the total power failure on 1/16/18. For causes and corrective actions, see the root cause and corrective action analysis dated 1/16/18 in Appendix B of this report.	
1/24/18		08:00				
1/27/18	03:00	15:00	12	371	SO ₂ at 0% O ₂ greater than 250 ppm, 12-HRA, with SO ₂ emissions less than 500 lbs/day above the allowable limit following the introduction of acid gas feed following the total power failure on 1/16/18. For causes and corrective actions, see the root cause and corrective action analysis dated 1/16/18 in Appendix B of this report.	
TOTAL			12			

Ja CMS PERFORMANCE¹						
Date	Start	End	Duration (hours)	Cause	Corrective Action	
3/6/18	13:00	14:00	1	Offline for preventative maintenance.	Calibrated and returned to service.	
TOTAL			1			

¹In accordance with 40 CFR 60.108a(d)(6), changes made in operation of the emission control system during the period of data unavailability which could affect the ability of the system to meet the applicable emission limit have been compared with operation of the control system and affected facility before and following the period of data unavailability to ensure that any changes made in operation of the emission control system during the period of data unavailability did not affect the ability of the system to meet the applicable emission limit.

**GASEOUS AND OPACITY EXCESS EMISSIONS AND
MONITORING SYSTEMS PERFORMANCE**

(per 40 CFR 60.7(c) and 60.108a(d))

Pollutant: **SO₂**

Applicable NSPS Subpart: Ja

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: SO₂ corrected to 0% O₂ shall not exceed 250 ppm on a 12-hour rolling average.

Monitor Manufacturer and Model No.: ABB AO2000 Uras 26(SO₂)/ Magnos 206 (O₂)

Date of Latest CMS Certification or Audit: CGA on 1/10/18

Process Unit(s) Description: #3 SRU Incinerator (EPN 5-00, EQT 0079)

Total source operating time in reporting period: 2,080 hours

Ja EXCESS EMISSIONS						
Date	Start	End	Duration (hours)	Max 12-HRA (ppm)	Cause	Corrective Action
1/2/18	12:00		30	685	SO ₂ at 0% O ₂ greater than 250 ppm, 12-HRA, with SO ₂ emissions greater than 500 lbs/day above the allowable limit due to an upset of the refinery steam system. For causes and corrective actions, see the root cause and corrective action analysis dated 1/12/18 in Appendix B of this report.	
1/3/18		18:00				
1/20/18	17:00		42	939	SO ₂ at 0% O ₂ greater than 250 ppm, 12-HRA, with SO ₂ emissions greater than 500 lbs/day above the allowable limit while operating in hot standby following the total power failure on 1/16/18. For causes and corrective actions, see the root cause and corrective action analysis dated 1/16/18 in Appendix B of this report.	
1/22/18		11:00				
3/22/18	14:00		15	517	SO ₂ at 0% O ₂ greater than 250 ppm, 12-HRA, with SO ₂ emissions greater than 500 lbs/day above the allowable limit following the introduction of acid gas feed following the Hydrocracker upset on 3/21/18. For causes and corrective actions, see the root cause and corrective action analysis dated 3/21/18 in Appendix B of this report.	
3/23/18		05:00				
TOTAL			87			

Ja CMS PERFORMANCE¹						
Date	Start	End	Duration (hours)	Cause	Corrective Action	
1/10/18	10:00	11:00	1	SO ₂ and O ₂ Cylinder Gas Audit.	N/A	
TOTAL			1			

¹In accordance with 40 CFR 60.108a(d)(6), changes made in operation of the emission control system during the period of data unavailability which could affect the ability of the system to meet the applicable emission limit have been compared with operation of the control system and affected facility before and following the period of data unavailability to ensure that any changes made in operation of the emission control system during the period of data unavailability did not affect the ability of the system to meet the applicable emission limit.

**GASEOUS AND OPACITY EXCESS EMISSIONS AND
MONITORING SYSTEMS PERFORMANCE**

(per 40 CFR 60.7(c) and 60.108a(d))

Pollutant: **H₂S**

Applicable NSPS Subpart: Ja

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Hydrogen Sulfide shall not exceed 162 ppm on a 3-hour rolling average and 60 ppm on a 365 day rolling average

Monitor Manufacturer and Model No.: Ametek 4661

Date of Latest CMS Certification or Audit: CGA on 1/26/18

Process Unit(s) Description: Area 2 Fuel Drum for Benzene Recovery Unit Reboiler (EPN 1-09, EQT 0127)

Total source operating time in reporting period: 1,704 hours

Ja EXCESS EMISSIONS						
Date	Start	End	Duration (hours)	Max 3-HRA (ppm)	Cause	Corrective Action
3/5/18	10:00	12:00	2	204	H ₂ S greater than 162 ppm, 3-HRA, with SO ₂ emissions less than 500 lbs/day above the allowable limit from the Benzene Recovery Unit Reboiler due to a trip of the Main Burner in the #3 SRU. The Main Burner tripped on low air flow after the steam driven blower was hit with a slug of water that reduced its speed.	Valero determined that the slug of water came from a deadleg of steam piping in the #3 SRU due to several steam traps being isolated or not functioning. Valero has repaired and/or placed these steam traps in service.
TOTAL			2			

Ja CMS PERFORMANCE¹						
Date	Start	End	Duration (hours)	Cause	Corrective Action	
None						
TOTAL			0			

¹In accordance with 40 CFR 60.108a(d)(6), changes made in operation of the emission control system during the period of data unavailability which could affect the ability of the system to meet the applicable emission limit have been compared with operation of the control system and affected facility before and following the period of data unavailability to ensure that any changes made in operation of the emission control system during the period of data unavailability did not affect the ability of the system to meet the applicable emission limit.

**GASEOUS AND OPACITY EXCESS EMISSIONS AND
MONITORING SYSTEMS PERFORMANCE**

(per 40 CFR 60.7(c) and 60.108a(d))

Pollutant: **NO_x**

Applicable NSPS Subpart: Ja

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Nitrogen Oxide corrected to 0% O₂ shall not exceed 40 ppm on a 30-day rolling average

Monitor Manufacturer and Model No.: Thermo Environmental 42i (NO_x)/(O₂)

Date of Latest CMS Certification or Audit: CGA on 1/14/18

Process Unit(s) Description: Benzene Recovery Unit Reboiler (EPN 1-09, EQT 0127)

Total source operating time in reporting period: 1,704 hours

Ja EXCESS EMISSIONS						
Date	Start	End	Duration (hours)	Max 30-DRA (ppm)	Cause	Corrective Action
None						
TOTAL			0			

Ja CMS PERFORMANCE¹					
Date	Start	End	Duration (hours)	Cause	Corrective Action
1/14/18	11:00	12:00	1	NO _x and O ₂ Cylinder Gas Audit	N/A
TOTAL			1		

¹In accordance with 40 CFR 60.108a(d)(6), changes made in operation of the emission control system during the period of data unavailability which could affect the ability of the system to meet the applicable emission limit have been compared with operation of the control system and affected facility before and following the period of data unavailability to ensure that any changes made in operation of the emission control system during the period of data unavailability did not affect the ability of the system to meet the applicable emission limit.

**GASEOUS AND OPACITY EXCESS EMISSIONS AND
MONITORING SYSTEMS PERFORMANCE**

(per 40 CFR 60.7(c) and 60.108a(d))

Pollutant: **H₂S**

Applicable NSPS Subpart: Ja

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Hydrogen Sulfide shall not exceed 162 ppm on a 3-hour rolling average.

Monitor Manufacturer and Model No.: Ametek 5100

Date of Latest CMS Certification or Audit: CGA on 1/11/18

Process Unit(s) Description: North Flare Stack (EPN 20-72, EQT 0035), North Flare Header

Total source operating time in reporting period: 2,159 hours

Ja EXCESS EMISSIONS						
Date	Start	End	Duration (hours)	Max 3-HRA (ppm)	Cause	Corrective Action
1/2/18	08:00	12:00	4	292	H ₂ S greater than 162 ppm, 3-HRA due to the loss of the Flare Gas Recovery Compressor due to unusually cold conditions. For causes and corrective actions, see the root cause and corrective action analysis dated 1/2/18 attached at the end of this report.	
1/11/18	11:00	12:00	1	167	H ₂ S greater than 162 ppm, 3-HRA due to the Flare Gas Recovery Compressor trip during start up/swapping operations.	Valero re-started a Flare Gas Compressor.
1/15/18	18:00	05:00	11	281	H ₂ S greater than 162 ppm, 3-HRA due to the loss of the Flare Gas Recovery Compressor due to inlet strainer plugging. For causes and corrective actions, see the root cause and corrective action analysis dated 1/15/18 attached at the end of this report.	
2/6/18	15:00	16:00	1	189	H ₂ S greater than 162 ppm, 3-HRA due to the Flare Gas Recovery Compressor trip during start up/swapping operations due to a cooling fan breaking.	Valero re-started a Flare Gas Compressor and replaced the cooling fan belt.
TOTAL			17			

**GASEOUS AND OPACITY EXCESS EMISSIONS AND
MONITORING SYSTEMS PERFORMANCE**

(per 40 CFR 60.7(c) and 60.108a(d))

Pollutant: **H₂S**

Applicable NSPS Subpart: Ja

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Hydrogen Sulfide shall not exceed 162 ppm on a 3-hour rolling average.

Monitor Manufacturer and Model No.: Ametek 5100

Date of Latest CMS Certification or Audit: CGA on 1/11/18

Process Unit(s) Description: North Flare Stack (EPN 20-72, EQT 0035), North Flare Header

Total source operating time in reporting period: 2,159 hours

Ja CMS PERFORMANCE ²					
Date	Start	End	Duration (hours)	Cause	Corrective Action
None					
TOTAL			0		

¹Due to the physical arrangement of the headers supplying the North Flare Stack (EPN 20-72, EQT 0035), two analyzers are required to measure H₂S concentration of the gas combusted in the North Flare. Conservatively, excess emission on either of these analyzers will be considered excess emissions at the North Flare. However, the CEMS performance will be tracked separately.

²In accordance with 40 CFR 60.108a(d)(6), changes made in operation of the emission control system during the period of data unavailability which could affect the ability of the system to meet the applicable emission limit have been compared with operation of the control system and affected facility before and following the period of data unavailability to ensure that any changes made in operation of the emission control system during the period of data unavailability did not affect the ability of the system to meet the applicable emission limit.

**GASEOUS AND OPACITY EXCESS EMISSIONS AND
MONITORING SYSTEMS PERFORMANCE**

(per 40 CFR 60.7(c) and 60.108a(d))

Pollutant: **H₂S**

Applicable NSPS Subpart: Ja

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Hydrogen Sulfide shall not exceed 162 ppm on a 3-hour rolling average.

Monitor Manufacturer and Model No.: Ametek 5100

Date of Latest CMS Certification or Audit: CGA on 1/10/18

Process Unit(s) Description: North Flare Stack (EPN 20-72, EQT 0035), Hydrocracker Flare Header

Total source operating time in reporting period: 2,159 hours

Ja EXCESS EMISSIONS						
Date	Start	End	Duration (hours)	Max 3-HRA (ppm)	Cause	Corrective Action
1/2/18	08:00	12:00	4	292	H ₂ S greater than 162 ppm, 3-HRA due to the loss of the Flare Gas Recovery Compressor due to unusually cold conditions. For causes and corrective actions, see the root cause and corrective action analysis dated 1/2/18 attached at the end of this report.	
1/11/18	11:00	12:00	1	167	H ₂ S greater than 162 ppm, 3-HRA due to the Flare Gas Recovery Compressor trip during start up/swapping operations.	Valero re-started a Flare Gas Compressor.
1/15/18	18:00	05:00	11	281	H ₂ S greater than 162 ppm, 3-HRA due to the loss of the Flare Gas Recovery Compressor due to inlet strainer plugging. For causes and corrective actions, see the root cause and corrective action analysis dated 1/15/18 attached at the end of this report.	
2/6/18	15:00	16:00	1	189	H ₂ S greater than 162 ppm, 3-HRA due to the Flare Gas Recovery Compressor trip during start up/swapping operations due to a cooling fan breaking.	Valero re-started a Flare Gas Compressor and replaced the cooling fan belt.
TOTAL			17			

**GASEOUS AND OPACITY EXCESS EMISSIONS AND
MONITORING SYSTEMS PERFORMANCE**

(per 40 CFR 60.7(c) and 60.108a(d))

Pollutant: **H₂S**

Applicable NSPS Subpart: Ja

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Hydrogen Sulfide shall not exceed 162 ppm on a 3-hour rolling average.

Monitor Manufacturer and Model No.: Ametek 5100

Date of Latest CMS Certification or Audit: CGA on 1/10/18

Process Unit(s) Description: North Flare Stack (EPN 20-72, EQT 0035), Hydrocracker Flare Header

Total source operating time in reporting period: 2,159 hours

Ja CMS PERFORMANCE ²					
Date	Start	End	Duration (hours)	Cause	Corrective Action
1/10/18	14:00	15:00	1	Cylinder Gas Audit	N/A
1/29/18	07:00	09:00	2	Analyzer malfunctioned during daily calibration check and did not return to sample.	Valero reset and calibrated the analyzer and returned it to service.
TOTAL			3		

¹Due to the physical arrangement of the headers supplying the North Flare Stack (EPN 20-72, EQT 0035), two analyzers are required to measure H₂S concentration of the gas combusted in the North Flare. Conservatively, excess emission on either of these analyzers will be considered excess emissions at the North Flare. However, the CEMS performance will be tracked separately.

²In accordance with 40 CFR 60.108a(d)(6), changes made in operation of the emission control system during the period of data unavailability which could affect the ability of the system to meet the applicable emission limit have been compared with operation of the control system and affected facility before and following the period of data unavailability to ensure that any changes made in operation of the emission control system during the period of data unavailability did not affect the ability of the system to meet the applicable emission limit.

**GASEOUS AND OPACITY EXCESS EMISSIONS AND
MONITORING SYSTEMS PERFORMANCE**

(per 40 CFR 60.7(c) and 60.108a(d))

Pollutant: **H₂S**

Applicable NSPS Subpart: Ja

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Hydrogen Sulfide shall not exceed 162 ppm on a 3-hour rolling average.

Monitor Manufacturer and Model No.: Ametek 5100

Date of Latest CMS Certification or Audit: CGA on 1/12/18

Process Unit(s) Description: South Flare Stack (EPN 3-77, EQT 0049)

Total source operating time in reporting period: 2,159 hours

Ja EXCESS EMISSIONS						
Date	Start	End	Duration (hours)	Max 3-HRA (ppm)	Cause	Corrective Action
1/11/18	11:00	12:00	1	167	H ₂ S greater than 162 ppm, 3-HRA due to the Flare Gas Recovery Compressor trip during start up/swapping operations.	Valero re-started a Flare Gas Compressor.
1/15/18	18:00	05:00	11	281	H ₂ S greater than 162 ppm, 3-HRA due to the loss of the Flare Gas Recovery Compressor due to inlet strainer plugging. For causes and corrective actions, see the root cause and corrective action analysis dated 1/15/18 attached at the end of this report.	
TOTAL			12			

Ja CMS PERFORMANCE ¹						
Date	Start	End	Duration (hours)	Cause	Corrective Action	
None						
TOTAL			0			

¹In accordance with 40 CFR 60.108a(d)(6), changes made in operation of the emission control system during the period of data unavailability which could affect the ability of the system to meet the applicable emission limit have been compared with operation of the control system and affected facility before and following the period of data unavailability to ensure that any changes made in operation of the emission control system during the period of data unavailability did not affect the ability of the system to meet the applicable emission limit.

**GASEOUS AND OPACITY EXCESS EMISSIONS AND
MONITORING SYSTEMS PERFORMANCE**

(per 40 CFR 60.7(c) and 60.108a(d))

Pollutant: **Total Sulfur**

Applicable NSPS Subpart: Ja (Required by Consent Decree: 3:10-cv-00563-bbc, Paragraph 49.a.ii)

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: None

Monitor Manufacturer and Model No.: Thermo Scientific SOLA II

Date of Latest CMS Certification or Audit: CGA on 1/12/18

Process Unit(s) Description: North Flare Stack (EPN 20-72, EQT 0035), North Flare Header

Total source operating time in reporting period: 2,159 hours

Ja CMS PERFORMANCE¹					
Date	Start	End	Duration (hours)	Cause	Corrective Action
1/12/18	10:00	11:00	1	Cylinder Gas Audit.	N/A
1/16/18	21:00		20	Analyzer shutdown due to a total power failure.	Valero started up, calibrated, and returned the analyzer to service.
1/17/18		17:00			
3/8/18	09:00	10:00	1	Analyzer adjusted for calibration drift.	Calibrated and returned to service.
3/14/18	08:00	09:00	1	Analyzer adjusted for calibration drift.	Calibrated and returned to service.
3/14/18	13:00	14:00	1	Analyzer adjusted for calibration drift.	Calibrated and returned to service.
3/26/18	10:00	11:00	1	Analyzer adjusted for calibration drift.	Calibrated and returned to service.
TOTAL			25		

¹In accordance with 40 CFR 60.108a(d)(6), changes made in operation of the emission control system during the period of data unavailability which could affect the ability of the system to meet the applicable emission limit have been compared with operation of the control system and affected facility before and following the period of data unavailability to ensure that any changes made in operation of the emission control system during the period of data unavailability did not affect the ability of the system to meet the applicable emission limit.

**GASEOUS AND OPACITY EXCESS EMISSIONS AND
MONITORING SYSTEMS PERFORMANCE**

(per 40 CFR 60.7(c) and 60.108a(d))

Pollutant: **Total Sulfur**

Applicable NSPS Subpart: Ja (Also Required by Consent Decree: 3:10-cv-00563-bbc, Paragraph 49.a.ii)

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: None

Monitor Manufacturer and Model No.: Thermo Scientific SOLA II

Date of Latest CMS Certification or Audit: CGA on 1/12/18

Process Unit(s) Description: North Flare Stack (EPN 20-72, EQT 0035), Hydrocracker Flare Header

Total source operating time in reporting period: 2,159 hours

Ja CMS PERFORMANCE ¹					
Date	Start	End	Duration (hours)	Cause	Corrective Action
1/16/18	21:00		19	Analyzer shutdown due to a total power failure.	Valero started up, calibrated, and returned the analyzer to service.
1/17/18		16:00			
3/14/18	09:00	11:00	2	Analyzer adjusted for calibration drift.	Calibrated and returned to service.
TOTAL			21		

¹In accordance with 40 CFR 60.108a(d)(6), changes made in operation of the emission control system during the period of data unavailability which could affect the ability of the system to meet the applicable emission limit have been compared with operation of the control system and affected facility before and following the period of data unavailability to ensure that any changes made in operation of the emission control system during the period of data unavailability did not affect the ability of the system to meet the applicable emission limit.

**GASEOUS AND OPACITY EXCESS EMISSIONS AND
MONITORING SYSTEMS PERFORMANCE**

(per 40 CFR 60.7(c) and 60.108a(d))

Pollutant: **Total Sulfur**

Applicable NSPS Subpart: Ja (Also Required by Consent Decree: 3:10-cv-00563-bbc, Paragraph 49.a.ii)

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: None

Monitor Manufacturer and Model No.: Thermo Scientific SOLA II

Date of Latest CMS Certification or Audit: CGA on 1/27/18

Process Unit(s) Description: South Flare Stack (EPN 3-77, EQT 0049)

Total source operating time in reporting period: 2,159 hours

Ja CMS PERFORMANCE ¹					
Date	Start	End	Duration (hours)	Cause	Corrective Action
1/16/18	21:00		18	Analyzer shutdown due to a total power failure.	Valero started up, calibrated, and returned the analyzer to service.
1/17/18		15:00			
1/27/18	09:00	10:00	1	Cylinder Gas Audit.	N/A
2/12/18	10:00	11:00	1	Analyzer adjusted for calibration drift.	Calibrated and returned to service.
3/11/18	12:00	13:00	1	Analyzer adjusted for calibration drift.	Calibrated and returned to service.
3/12/18	10:00	11:00	1	Analyzer adjusted for calibration drift.	Calibrated and returned to service.
3/15/18	11:00	12:00	1	Analyzer adjusted for calibration drift.	Calibrated and returned to service.
TOTAL			23		

¹In accordance with 40 CFR 60.108a(d)(6), changes made in operation of the emission control system during the period of data unavailability which could affect the ability of the system to meet the applicable emission limit have been compared with operation of the control system and affected facility before and following the period of data unavailability to ensure that any changes made in operation of the emission control system during the period of data unavailability did not affect the ability of the system to meet the applicable emission limit.

**GASEOUS AND OPACITY EXCESS EMISSIONS AND
MONITORING SYSTEMS PERFORMANCE**

(per 40 CFR 60.7(c) and 60.108a(d))

Pollutant: **Flow**

Applicable NSPS Subpart: Ja (Also Required by Consent Decree: 3:10-cv-00563-bbc, Paragraph 49.a.ii)

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: None

Monitor Manufacturer and Model No.: GE Panametrics GF 868

Date of Latest CMS Certification or Audit: N/A

Process Unit(s) Description: North Flare Stack (EPN 20-72, EQT 0035), North Flare Header

Total source operating time in reporting period: 2,159 hours

Ja CMS PERFORMANCE ¹					
Date	Start	End	Duration (hours)	Cause	Corrective Action
1/16/18	21:00		13	Flowmeter shutdown or data unavailable due to a total power failure.	Returned to service.
1/17/18		10:00			
2/23/18	08:00	15:00	7	Flowmeter shutdown for annual preventative maintenance.	Returned to service.
TOTAL			20		

¹In accordance with 40 CFR 60.108a(d)(6), changes made in operation of the emission control system during the period of data unavailability which could affect the ability of the system to meet the applicable emission limit have been compared with operation of the control system and affected facility before and following the period of data unavailability to ensure that any changes made in operation of the emission control system during the period of data unavailability did not affect the ability of the system to meet the applicable emission limit.

**GASEOUS AND OPACITY EXCESS EMISSIONS AND
MONITORING SYSTEMS PERFORMANCE**

(per 40 CFR 60.7(c) and 60.108a(d))

Pollutant: **Flow**

Applicable NSPS Subpart: Ja (Also Required by Consent Decree: 3:10-cv-00563-bbc, Paragraph 49.a.ii)

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: None

Monitor Manufacturer and Model No.: GE Panametrics GF 868

Date of Latest CMS Certification or Audit: N/A

Process Unit(s) Description: North Flare Stack (EPN 20-72, EQT 0035), Hydrocracker Flare Header

Total source operating time in reporting period: 2,159 hours

Ja CMS PERFORMANCE ¹					
Date	Start	End	Duration (hours)	Cause	Corrective Action
1/16/18	21:00		5	Flowmeter shutdown or data unavailable due to a total power failure.	Returned to service.
1/17/18		02:00			
1/17/18	03:00	06:00			
1/17/18	07:00	10:00	3		
TOTAL			11		

¹In accordance with 40 CFR 60.108a(d)(6), changes made in operation of the emission control system during the period of data unavailability which could affect the ability of the system to meet the applicable emission limit have been compared with operation of the control system and affected facility before and following the period of data unavailability to ensure that any changes made in operation of the emission control system during the period of data unavailability did not affect the ability of the system to meet the applicable emission limit.

**GASEOUS AND OPACITY EXCESS EMISSIONS AND
MONITORING SYSTEMS PERFORMANCE**

(per 40 CFR 60.7(c) and 60.108a(d))

Pollutant: **Flow**

Applicable NSPS Subpart: Ja (Also Required by Consent Decree: 3:10-cv-00563-bbc, Paragraph 49.a.ii)

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: None

Monitor Manufacturer and Model No.: GE Panametrics GF 868

Date of Latest CMS Certification or Audit: N/A

Process Unit(s) Description: South Flare Stack (EPN 3-77, EQT 0049)

Total source operating time in reporting period: 2,159 hours

Ja CMS PERFORMANCE ¹					
Date	Start	End	Duration (hours)	Cause	Corrective Action
1/16/18	21:00		5	Flowmeter shutdown or data unavailable due to a total power failure.	Returned to service.
1/17/18		02:00			
1/17/18	07:00	10:00	3		
2/21/18	14:00	20:00	6	Flowmeter shutdown for annual preventative maintenance.	Returned to service.
2/22/18	09:00	12:00	3		
2/23/18	12:00	15:00	3		
TOTAL			20		

¹In accordance with 40 CFR 60.108a(d)(6), changes made in operation of the emission control system during the period of data unavailability which could affect the ability of the system to meet the applicable emission limit have been compared with operation of the control system and affected facility before and following the period of data unavailability to ensure that any changes made in operation of the emission control system during the period of data unavailability did not affect the ability of the system to meet the applicable emission limit.

DATA ASSESSMENT REPORT

(per 40 CFR 60, Appendix F, Section 7)

Pollutant: **SO₂**

Applicable NSPS Subpart: Ja

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: SO₂ corrected to 0% O₂ shall not exceed 250 ppm on a 12-hour rolling average.

Monitor Manufacturer and Model No.: Brimstone SGX-231(SO₂)/Rosemount Oxymitter 4000(O₂)

Source unit: #2 SRU Incinerator (EPN 1-93, EQT 0019)

CEM Sampling Location: #2 SRU Incinerator (#1-93)

CEM Span Value: Sulfur Dioxide 500 ppm; Oxygen 25%

I. ACCURACY ASSESSMENT RESULTS (CGA):

	SO ₂ #1 <u>(low scale)</u>	SO ₂ #2 <u>(high scale)</u>	O ₂ #1 <u>(low scale)</u>	O ₂ #2 <u>(high scale)</u>
Date of Audit	1/16/18	1/16/18	1/16/18	1/16/18
Audit Gas Cylinder No.	SG9150051BAL	CC125741	CC483689	SG9152263BAL
Date of Audit Gas Cert.	5/27/16	5/27/16	5/23/16	5/23/16
Type of Certification	EPA Protocol 1	EPA Protocol 1	EPA Protocol 1	EPA Protocol 1
Certified Audit Value	124.9 ppmv	274.5 ppmv	5.99 vol %	10.05 vol %
CEM Response Value	129.7 ppmv	276.3 ppmv	6.20 vol %	10.17 vol %
Accuracy	3.8%	0.7%	3.5%	1.2%
Standard	<15%	<15%	<15%	<15%

II. CALIBRATION DRIFT ASSESSMENT

A. Out of Control Periods:

1. Dates: N/A

2. Number of Days N/A

B. Corrective Actions: N/A

DATA ASSESSMENT REPORT

(per 40 CFR 60, Appendix F, Section 7)

Pollutant: **SO₂**

Applicable NSPS Subpart: Ja

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: SO₂ corrected to 0% O₂ shall not exceed 250 ppm on a 12-hour rolling average.

Monitor Manufacturer and Model No.: ABB AO2000 Uras 26(SO₂)/ Magnos 206 (O₂)

Source unit: #3 SRU Incinerator (EPN 5-00, EQT 0079)

CEM Sampling Location: #3 SRU Incinerator (#5-00)

CEM Span Value: Sulfur Dioxide 500 ppm; Oxygen 25%

I. ACCURACY ASSESSMENT RESULTS (CGA):

	SO ₂ #1 <u>(low scale)</u>	SO ₂ #2 <u>(high scale)</u>	O ₂ #1 <u>(low scale)</u>	O ₂ #2 <u>(high scale)</u>
Date of Audit	1/10/18	1/10/18	1/10/18	1/10/18
Audit Gas Cylinder No.	XC022957B	CC94008	CC483694	EB0063979
Date of Audit Gas Cert.	5/27/16	5/27/16	5/23/16	5/23/16
Type of Certification	EPA Protocol 1	EPA Protocol 1	EPA Protocol 1	EPA Protocol 1
Certified Audit Value	125.3 ppmv	275.3 ppmv	5.99 vol %	9.98 vol %
CEM Response Value	129.3 ppmv	281.6 ppmv	6.12 vol %	10.14 vol %
Accuracy	3.2%	2.3%	2.2%	1.6%
Standard	<15%	<15%	<15%	<15%

II. CALIBRATION DRIFT ASSESSMENT

A. Out of Control Periods:

1. Dates: N/A

2. Number of Days N/A

B. Corrective Actions: N/A

DATA ASSESSMENT REPORT

(per 40 CFR 60, Appendix F, Section 7)

Pollutant: **H₂S**

Applicable NSPS Subpart: J

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Hydrogen Sulfide shall not exceed 162 ppm on a 3-hour rolling average.

Monitor Manufacturer and Model No.: Ametek 4661

Source Unit: Area 1 Fuel Drum for Boiler TB-01 (EPN 1-06, EQT 0010)

CEM Sampling Location: Area 1 Fuel Drum

CEM Span Value: Hydrogen Sulfide, 300 ppm

I. ACCURACY ASSESSMENT RESULTS (CGA):

	H ₂ S #1 <u>(low scale)</u>	H ₂ S #2 <u>(high scale)</u>
Date of Audit	1/12/18	1/12/18
Audit Gas Cylinder No.	XC034939B	CC26703
Date of Audit Gas Cert.	5/23/16	5/27/16
Type of Certification	EPA Protocol 1	EPA Protocol 1
Certified Audit Value (ppmv)	76.0	175.3
CEM Response Value (ppmv)	79.7	181.3
Accuracy	4.9%	3.4%
Standard	<15%	<15%

II. CALIBRATION DRIFT ASSESSMENT

A. Out of Control Periods:

1. Dates: N/A

2. Number of Days N/A

B. Corrective Actions: N/A

DATA ASSESSMENT REPORT

(per 40 CFR 60, Appendix F, Section 7)

Pollutant: **H₂S**

Applicable NSPS Subpart: J and Ja (Benzene Recovery Unit Reboiler Subject to Ja)

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Hydrogen Sulfide shall not exceed 162 ppm on a 3-hour rolling average(J and Ja) and 60 ppm on a 365 day rolling average (Ja only)

Monitor Manufacturer and Model No.: Ametek 4661

Source Unit: Area 2 Fuel Drum for: MDH Product and Fractionator Heaters (EPN 2-92, EQT 0033); No.1 Crude Heater (EPN 12-72A, EQT 022); ROSE Heater (EPN 1-80, EQT 0014); Vacuum Heater (EPN 1-76, EQT 0013); Platformer Charge Heater (EPN 17-72 a,b,c , EQT 0028); Platformer Debut Reboiler (EPN 19-72, EQT 0029); NHT Charge Heater (EPN 14-72, EQT 0023); NHT Debut Reboiler (EPA 15-72, EQT 0024); NHT Depent Reboiler (EPA 16-72, EQT 0027); DHT Charge Heater (EPN 5-73, EQT 0058); Benzene Recovery Unit Reboiler (EPN 1-09, EQT 0127)

CEM Sampling Location: Area 2 Fuel Drum

CEM Span Value: Hydrogen Sulfide, 300 ppm

I. ACCURACY ASSESSMENT RESULTS (CGA):

	H ₂ S #1 <u>(low scale)</u>	H ₂ S #2 <u>(high scale)</u>
Date of Audit	1/26/18	1/26/18
Audit Gas Cylinder No.	EB0062585	CC41503
Date of Audit Gas Cert.	5/23/16	5/27/16
Type of Certification	EPA Protocol 1	EPA Protocol 1
Certified Audit Value (ppmv)	76.7	176.4
CEM Response Value (ppmv)	74.0	171.0
Accuracy	3.5%	3.1%
Standard	<15%	<15%

II. CALIBRATION DRIFT ASSESSMENT

A. Out of Control Periods:

1. Dates: N/A

2. Number of Days N/A

B. Corrective Actions: N/A

DATA ASSESSMENT REPORT

(per 40 CFR 60, Appendix F, Section 7)

Pollutant: **H₂S**

Applicable NSPS Subpart: J

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Hydrogen Sulfide shall not exceed 162 ppm on a 3-hour rolling average.

Monitor Manufacturer and Model No.: Ametek 4661

Process Unit(s) Description: Area 4 Fuel Drum for Merox Disulfide Separator to Platformer Charge Heater

CEM Sampling Location: Area 4 Fuel Drum

CEM Span Value: Hydrogen Sulfide, 300 ppm

I. ACCURACY ASSESSMENT RESULTS (CGA):

	H ₂ S #1 <u>(low scale)</u>	H ₂ S #2 <u>(high scale)</u>
Date of Audit	1/26/18	1/26/18
Audit Gas Cylinder No.	CC467104	CC91595
Date of Audit Gas Cert.	5/23/16	5/27/16
Type of Certification	EPA Protocol 1	EPA Protocol 1
Certified Audit Value (ppmv)	78.0	169.9
CEM Response Value (ppmv)	76.7	167.3
Accuracy	1.7%	1.5%
Standard	<15%	<15%

II. CALIBRATION DRIFT ASSESSMENT

A. Out of Control Periods:

1. Dates: N/A

2. Number of Days N/A

B. Corrective Actions: N/A

DATA ASSESSMENT REPORT

(per 40 CFR 60, Appendix F, Section 7)

Pollutant: **H₂S**

Applicable NSPS Subpart: J

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Hydrogen Sulfide shall not exceed 162 ppm on a 3-hour rolling average.

Monitor Manufacturer and Model No.: Ametek 4661

Process Unit(s) Description: Area 6 Fuel Drum for Hydrocracker & Hydrotreater Charge Heaters (EPN 1-00, EQT 0009)

CEM Sampling Location: Area 6 Fuel Drum

CEM Span Value: Hydrogen Sulfide, 300 ppm

I. ACCURACY ASSESSMENT RESULTS (CGA):

	H ₂ S #1 <u>(low scale)</u>	H ₂ S #2 <u>(high scale)</u>
Date of Audit	1/12/18	1/12/18
Audit Gas Cylinder No.	CC182529	CC52088
Date of Audit Gas Cert.	5/23/16	5/27/16
Type of Certification	EPA Protocol 1	EPA Protocol 1
Certified Audit Value (ppmv)	78.4	166.7
CEM Response Value (ppmv)	79.7	166.0
Accuracy	1.7%	0.4%
Standard	<15%	<15%

II. CALIBRATION DRIFT ASSESSMENT

A. Out of Control Periods:

1. Dates: N/A

2. Number of Days N/A

B. Corrective Actions: N/A

DATA ASSESSMENT REPORT

(per 40 CFR 60, Appendix F, Section 7)

Pollutant: **H₂S**

Applicable NSPS Subpart: J

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Hydrogen Sulfide shall not exceed 162 ppm on a 3-hour rolling average.

Monitor Manufacturer and Model No.: Ametek 4661

Process Unit(s) Description: Area 6 Fuel Drum for Boilers B-5 (EPN 2-00, EQT 0030) and B-6 (EPN 3-00, EQT 0048)

CEM Sampling Location: Area 6 Fuel Drum

CEM Span Value: Hydrogen Sulfide, 300 ppm

I. ACCURACY ASSESSMENT RESULTS (CGA):

	H ₂ S #1 <u>(low scale)</u>	H ₂ S #2 <u>(high scale)</u>
Date of Audit	1/26/18	1/26/18
Audit Gas Cylinder No.	CC421903	CC111958
Date of Audit Gas Cert.	5/23/16	5/27/16
Type of Certification	EPA Protocol 1	EPA Protocol 1
Certified Audit Value (ppmv)	78.1	171.5
CEM Response Value (ppmv)	72.5	163.0
Accuracy	7.2%	5.0%
Standard	<15%	<15%

II. CALIBRATION DRIFT ASSESSMENT

A. Out of Control Periods:

1. Dates: N/A

2. Number of Days N/A

B. Corrective Actions: N/A

DATA ASSESSMENT REPORT

(per 40 CFR 60, Appendix F, Section 7)

Pollutant: **NO_x**

Applicable NSPS Subpart: Db

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Nitrogen Oxide shall not exceed 0.1 pound/MMBtu on a 30-day rolling average.

Monitor Manufacturer and Model No.: ABB Limas11(NO_x), Magnos27 (O₂)

Process Unit(s) Description: Boiler B-5 (EPN 2-00, EQT 0030)

CEM Sampling Location: Boiler B-5

CEM Span Value: Nitrogen Oxide 100 ppm, Oxygen 25 %

I. ACCURACY ASSESSMENT RESULTS (CGA):

	NO _x #1 <u>(low scale)</u>	NO _x #2 <u>(high scale)</u>	O ₂ #1 <u>(low scale)</u>	O ₂ #2 <u>(high scale)</u>
Date of Audit	1/23/18	1/23/18	1/23/18	1/23/18
Audit Gas Cylinder No.	CC330464	LL64747	LL53418	LL167062
Date of Audit Gas Cert.	6/2/16	5/3/16	1/28/14	1/28/14
Type of Certification	EPA Protocol 1	EPA Protocol 1	EPA Protocol 1	EPA Protocol 1
Certified Audit Value	25.2 ppmv	54.5 ppmv	6.01 vol %	10.01 vol %
CEM Response Value	25.5 ppmv	54.5 ppmv	5.92 vol %	9.93 vol %
Accuracy	1.2%	0.0%	1.5%	0.8%
Standard	<15%	<15%	<15%	<15%

II. CALIBRATION DRIFT ASSESSMENT

A. Out of Control Periods:

1. Dates: N/A

2. Number of Days N/A

B. Corrective Actions: N/A

DATA ASSESSMENT REPORT

(per 40 CFR 60, Appendix F, Section 7)

Pollutant: **NO_x**

Applicable NSPS Subpart: Db

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Nitrogen Oxide shall not exceed 0.1 pound/MMBtu on a 30-day rolling average.

Monitor Manufacturer and Model No.: ABB Limas11 (NO_x), Magnos27 (O₂)

Process Unit(s) Description: Boiler B-6 (EPN 3-00, EQT 0048)

CEM Sampling Location: Boiler B-6

CEM Span Value: Nitrogen Oxide 100 ppm, Oxygen 25 %

I. ACCURACY ASSESSMENT RESULTS (CGA):

	NO _x #1 <u>(low scale)</u>	NO _x #2 <u>(high scale)</u>	O ₂ #1 <u>(low scale)</u>	O ₂ #2 <u>(high scale)</u>
Date of Audit	1/23/18	1/23/18	1/23/18	1/23/18
Audit Gas Cylinder No.	CC330464	LL64747	LL53418	LL167062
Date of Audit Gas Cert.	6/2/16	5/3/16	1/28/14	1/28/14
Type of Certification	EPA Protocol 1	EPA Protocol 1	EPA Protocol 1	EPA Protocol 1
Certified Audit Value	25.2 ppmv	54.5 ppmv	6.01 vol %	10.01 vol %
CEM Response Value	24.6 ppmv	52.7 ppmv	5.90 vol %	9.92 vol %
Accuracy	2.4%	3.3%	1.8%	0.9%
Standard	<15%	<15%	<15%	<15%

II. CALIBRATION DRIFT ASSESSMENT

A. Out of Control Periods:

1. Dates: N/A

2. Number of Days N/A

B. Corrective Actions: N/A

DATA ASSESSMENT REPORT

(per 40 CFR 60, Appendix F, Section 7)

Pollutant: **NO_x**

Applicable NSPS Subpart: Db

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Nitrogen Oxide shall not exceed 0.1 pound/MMBtu on a 30-day rolling average.

Monitor Manufacturer and Model No.: Thermo Environmental Model 42i (NO_x)/(O₂)

Process Unit(s) Description: Boiler TB-01 (EPN 1-06, EQT 0010)

CEM Sampling Location: Boiler TB-01

CEM Span Value: Nitrogen Oxide 500 ppm, Oxygen 25 %

I. ACCURACY ASSESSMENT RESULTS (CGA):

	NO _x #1 <u>(low scale)</u>	NO _x #2 <u>(high scale)</u>	O ₂ #1 <u>(low scale)</u>	O ₂ #2 <u>(high scale)</u>
Date of Audit	1/25/18	1/25/18	1/25/18	1/25/18
Audit Gas Cylinder No.	SG9167966	CC89303	LL269	LL168197
Date of Audit Gas Cert.	5/31/16	5/31/16	4/26/16	4/25/16
Type of Certification	EPA Protocol 1	EPA Protocol 1	EPA Protocol 1	EPA Protocol 1
Certified Audit Value	126.9 ppmv	270.5 ppmv	6.03 vol %	10.10 vol %
CEM Response Value	132.7 ppmv	282.0 ppmv	6.00 vol %	10.10 vol %
Accuracy	4.6%	4.3%	0.5%	0.0%
Standard	<15%	<15%	<15%	<15%

II. CALIBRATION DRIFT ASSESSMENT

A. Out of Control Periods:

1. Dates: N/A

2. Number of Days N/A

B. Corrective Actions: N/A

DATA ASSESSMENT REPORT

(per 40 CFR 60, Appendix F, Section 7)

Pollutant: **NO_x**

Applicable NSPS Subpart: Ja

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Nitrogen Oxide corrected to 0% O₂ shall not exceed 40 ppm on a 30-day rolling average

Monitor Manufacturer and Model No.: Thermo Environmental Model 42i (NO_x)/(O₂)

Process Unit(s) Description: Benzene Recovery Unit Reboiler (EPN 1-09, EQT 0127)

CEM Sampling Location: Benzene Recovery Unit Reboiler

CEM Span Value: Nitrogen Oxide 100 ppm, Oxygen 25 %

I. ACCURACY ASSESSMENT RESULTS (CGA):

<u>CGA</u>	<u>NO_x #1 (low scale)</u>	<u>NO_x #2 (high scale)</u>	<u>O₂ #1 (low scale)</u>	<u>O₂ #2 (high scale)</u>
Date of Audit	1/14/18	1/14/18	1/14/18	1/14/18
Audit Gas Cylinder No.	CC430476	CC307733	CC483658	CC87078
Date of Audit Gas Cert.	6/2/16	6/2/16	5/23/16	5/23/16
Type of Certification	EPA Protocol 1	EPA Protocol 1	EPA Protocol 1	EPA Protocol 1
Certified Audit Value	25.0 ppmv	55.8 ppmv	5.96 vol %	9.94 vol %
CEM Response Value	24.3 ppmv	53.0 ppmv	5.60 vol %	9.43 vol %
Accuracy	2.8%	5.0%	6.0%	5.1%
Standard	<15%	<15%	<15%	<15%

II. CALIBRATION DRIFT ASSESSMENT

A. Out of Control Periods:

1. Dates: N/A

2. Number of Days N/A

B. Corrective Actions: N/A

DATA ASSESSMENT REPORT

(per 40 CFR 60, Appendix F, Section 7)

Pollutant: **NO_x**

Applicable NSPS Subpart: N/A (Required by Consent Decree: 3:10-cv-00563-bbc, Paragraph 36.a)

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Nitrogen Oxide corrected to 0% O₂ shall not exceed 40 ppm on a 30-day rolling average

Monitor Manufacturer and Model No.: Thermo Environmental Model 42i (NO_x)/(O₂)

Process Unit(s) Description: No.1 Crude Heater (EPN 12-72A, EQT 0022)

CEM Sampling Location: No.1 Crude Heater

CEM Span Value: Nitrogen Oxide 100 ppm, Oxygen 25 %

I. ACCURACY ASSESSMENT RESULTS (CGA):

<u>CGA</u>	<u>NO_x #1 (low scale)</u>	<u>NO_x #2 (high scale)</u>	<u>O₂ #1 (low scale)</u>	<u>O₂ #2 (high scale)</u>
Date of Audit	1/28/18	1/28/18	1/28/18	1/28/18
Audit Gas Cylinder No.	LL178685	CC319153	CC483638	CC222165
Date of Audit Gas Cert.	5/2/16	6/2/16	5/23/16	5/23/16
Type of Certification	EPA Protocol 1	EPA Protocol 1	EPA Protocol 1	EPA Protocol 1
Certified Audit Value	24.7 ppmv	55.4 ppmv	5.99 vol %	9.96 vol %
CEM Response Value	25.7 ppmv	58.9 ppmv	5.22 vol %	9.40 vol %
Accuracy	4.1%	6.3%	12.9%	5.6%
Standard	<15%	<15%	<15%	<15%

II. CALIBRATION DRIFT ASSESSMENT

A. Out of Control Periods:

1. Dates: N/A

2. Number of Days N/A

B. Corrective Actions: N/A

DATA ASSESSMENT REPORT

(per 40 CFR 60, Appendix F, Section 7)

Pollutant: **H₂S**

Applicable NSPS Subpart: Ja

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Hydrogen Sulfide shall not exceed 162 ppm on a 3-hour rolling average.

Monitor Manufacturer and Model No.: Ametek 5100

Process Unit(s) Description: North Flare Stack (EPN 20-72, EQT 0035), North Flare Header

CEM Sampling Location: North Flare Stack, North Flare Header (Y-AT-801)

CEM Span Value: Hydrogen Sulfide, 300 ppm

I. ACCURACY ASSESSMENT RESULTS (CGA):

	H ₂ S #1 <u>(low scale)</u>	H ₂ S #2 <u>(high scale)</u>
Date of Audit	1/11/18	1/11/18
Audit Gas Cylinder No.	CC441826	CC288207
Date of Audit Gas Cert.	10/3/16	10/4/16
Type of Certification	Certified Gas ¹	Certified Gas ¹
Certified Audit Value	79.1 ppmv	177.3 ppmv
CEM Response Value	79.3 ppmv	171.7 ppmv
Accuracy	0.3%	3.2%
Standard	<15%	<15%

¹ Valero unable to obtain EPA Protocol 1 certified gases for the Methane balanced audit gas required by this analyzer.

II. CALIBRATION DRIFT ASSESSMENT

A. Out of Control Periods:

1. Dates: N/A

2. Number of Days N/A

B. Corrective Actions: N/A

DATA ASSESSMENT REPORT

(per 40 CFR 60, Appendix F, Section 7)

Pollutant: **H₂S**

Applicable NSPS Subpart: Ja

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Hydrogen Sulfide shall not exceed 162 ppm on a 3-hour rolling average.

Monitor Manufacturer and Model No.: Ametek 5100

Process Unit(s) Description: North Flare Stack (EPN 20-72, EQT 0035), Hydrocracker Flare Header

CEM Sampling Location: North Flare Stack, Hydrocracker Flare Header (Y-AT-800)

CEM Span Value: Hydrogen Sulfide, 300 ppm

I. ACCURACY ASSESSMENT RESULTS (CGA):

	H ₂ S #1 <u>(low scale)</u>	H ₂ S #2 <u>(high scale)</u>
Date of Audit	1/10/18	1/10/18
Audit Gas Cylinder No.	CC416820	CC407913
Date of Audit Gas Cert.	10/3/16	10/4/16
Type of Certification	Certified Gas ¹	Certified Gas ¹
Certified Audit Value (ppmv)	81.5 ppmv	175.6 ppmv
CEM Response Value (ppmv)	75.0 ppmv	171.0 ppmv
Accuracy	8.0%	2.6%
Standard	<15%	<15%

¹ Valero unable to obtain EPA Protocol 1 certified gases for the Methane balanced audit gas required by this analyzer.

II. CALIBRATION DRIFT ASSESSMENT

A. Out of Control Periods:

1. Dates: N/A

2. Number of Days N/A

B. Corrective Actions: N/A

DATA ASSESSMENT REPORT

(per 40 CFR 60, Appendix F, Section 7)

Pollutant: **H₂S**

Applicable NSPS Subpart: Ja

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: Hydrogen Sulfide shall not exceed 162 ppm on a 3-hour rolling average.

Monitor Manufacturer and Model No.: Ametek 5100

Process Unit(s) Description: South Flare Stack (EPN 3-77, EQT 0049)

CEM Sampling Location: South Flare Stack (Y-AT-802)

CEM Span Value: Hydrogen Sulfide, 300 ppm

I. ACCURACY ASSESSMENT RESULTS (CGA):

	H ₂ S #1 <u>(low scale)</u>	H ₂ S #2 <u>(high scale)</u>
Date of Audit	1/12/18	1/12/18
Audit Gas Cylinder No.	CC416820	CC407913
Date of Audit Gas Cert.	10/3/16	10/4/16
Type of Certification	Certified Gas ¹	Certified Gas ¹
Certified Audit Value	81.5 ppmv	175.6 ppmv
CEM Response Value	81.0 ppmv	176.0 ppmv
Accuracy	0.6%	0.2%
Standard	<15%	<15%

¹ Valero unable to obtain EPA Protocol 1 certified gases for the Methane balanced audit gas required by this analyzer.

II. CALIBRATION DRIFT ASSESSMENT

A. Out of Control Periods:

1. Dates: N/A

2. Number of Days N/A

B. Corrective Actions: N/A

DATA ASSESSMENT REPORT

(per 40 CFR 60, Appendix F, Section 7)

Pollutant: **Total Sulfur**

Applicable NSPS Subpart: Ja (Required by Consent Decree: 3:10-cv-00563-bbc, Paragraph 49.a.ii)

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: None

Monitor Manufacturer and Model No.: Thermo Scientific SOLA II

Process Unit(s) Description: North Flare Stack (EPN 20-72, EQT 0035), North Flare Header

CEM Sampling Location: North Flare Stack, North Flare Header (Y-AT-303)

CEM Span Value: Total Sulfur, Dual Range: 0-10,000 ppm, 10,000-1,000,000 ppm

I. ACCURACY ASSESSMENT RESULTS (CGA):

	H ₂ S #1 <u>(low scale)</u>	H ₂ S #2 <u>(high scale)</u>
Date of Audit	1/12/18	1/12/18
Audit Gas Cylinder No.	CC305316	SG9152747BAL
Date of Audit Gas Cert.	5/27/16	7/27/17
Type of Certification	EPA Protocol 1	Primary Standard1
Certified Audit Value (ppmv)	1013.0 ppmv	9992.0 ppmv
CEM Response Value (ppmv)	1026.0 ppmv	10020.3 ppmv
Accuracy	1.3%	0.3%
Standard	<15%	<15%

¹ Valero unable to obtain EPA Protocol 1 certified gases greater than 1000 ppm.

II. CALIBRATION DRIFT ASSESSMENT

A. Out of Control Periods:

1. Dates: N/A

2. Number of Days N/A

B. Corrective Actions: N/A

DATA ASSESSMENT REPORT

(per 40 CFR 60, Appendix F, Section 7)

Pollutant: **Total Sulfur**

Applicable NSPS Subpart: Ja (Required by Consent Decree: 3:10-cv-00563-bbc, Paragraph 49.a.ii)

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: None

Monitor Manufacturer and Model No.: Thermo Scientific SOLA II

Process Unit(s) Description: North Flare Stack (EPN 20-72, EQT 0035), Hydrocracker Flare Header

CEM Sampling Location: North Flare Stack, Hydrocracker Flare Header (Y-AT-302)

CEM Span Value: Total Sulfur, Dual Range: 0-10,000 ppm, 10,000-1,000,000 ppm

I. ACCURACY ASSESSMENT RESULTS (CGA):

	H ₂ S #1 <u>(low scale)</u>	H ₂ S #2 <u>(high scale)</u>
Date of Audit	1/12/18	1/12/18
Audit Gas Cylinder No.	CC305316	SG9152747BAL
Date of Audit Gas Cert.	5/27/16	7/27/17
Type of Certification	EPA Protocol 1	Primary Standard ¹
Certified Audit Value (ppmv)	1013.0 ppmv	9992.0 ppmv
CEM Response Value (ppmv)	979.7 ppmv	9728.3 ppmv
Accuracy	3.3%	2.6%
Standard	<15%	<15%

¹ Valero unable to obtain EPA Protocol 1 certified gases greater than 1000 ppm.

II. CALIBRATION DRIFT ASSESSMENT

A. Out of Control Periods:

1. Dates: N/A

2. Number of Days N/A

B. Corrective Actions: N/A

DATA ASSESSMENT REPORT

(per 40 CFR 60, Appendix F, Section 7)

Pollutant: **Total Sulfur**

Applicable NSPS Subpart: Ja (Required by Consent Decree: 3:10-cv-00563-bbc, Paragraph 49.a.ii)

Reporting period dates: From 1/1/18 to 3/31/18

Date submitted: 4/30/18

Company: Valero Refining - Meraux LLC

Address: 2500 East St. Bernard Highway, Meraux, LA 70075

Emission Limitation: None

Monitor Manufacturer and Model No.: Thermo Scientific SOLA II

Process Unit(s) Description: South Flare Stack (EPN 3-77, EQT 0049)

CEM Sampling Location: South Flare Stack (Y-AT-304)

CEM Span Value: Total Sulfur, Dual Range: 0-10,000 ppm, 10,000-1,000,000 ppm

I. ACCURACY ASSESSMENT RESULTS (CGA):

	H ₂ S #1 <u>(low scale)</u>	H ₂ S #2 <u>(high scale)</u>
Date of Audit	1/27/18	1/27/18
Audit Gas Cylinder No.	CC305316	SG9152747BAL
Date of Audit Gas Cert.	5/27/16	7/27/17
Type of Certification	EPA Protocol 1	Primary Standard1
Certified Audit Value	1013.0 ppmv	9992.0 ppmv
CEM Response Value	1065.7 ppmv	10223.3 ppmv
Accuracy	5.2%	2.3%
Standard	<15%	<15%

¹ Valero unable to obtain EPA Protocol 1 certified gases greater than 1000 ppm.

II. CALIBRATION DRIFT ASSESSMENT

A. Out of Control Periods:

1. Dates: N/A

2. Number of Days N/A

B. Corrective Actions: N/A

Appendix A

Ja Root Cause and Corrective Action Analysis

Subpart Ja Root Cause / Corrective Action Analysis

Incident Number: 186191/186237

The information contained below satisfies the requirements of the NSPS Subpart Ja 60.108a(c)(6).

Report:	<u>Update</u>	
Refinery:	<u>Valero (Meraux)</u>	
Incident Type:	<u>Flaring (Flow and SO2), SRU (SO2)</u>	Date of Event: <u>10/12/17</u>
Emissions Source(s):	<u>North Flare (EPN 20-72, EQT 0035)</u> <u>South Flare (EPN 3-77, EQT 0049)</u> <u>#3 SRU Incinerator (EPN 5-00, EQT 0079)</u>	Date Analysis Completed: <u>11/20/17</u>

(1.) (60.108a(c)(6)(i))

A description of the Discharge:

At approximately 23:15 on 10/12/17, the Meraux Refinery experienced a partial loss of electrical power. Although the power was interruption was brief, multiple Refinery unit upsets and shutdowns were triggered. These upsets and shutdowns resulted in flaring and SO2 emissions from the North and South Flares > 500,000 SCF above baseline and > 500 lbs SO2 in a 24 hour period and SO2 emissions from the #3 SRU > 500 lbs above allowable in a 24 hour period.

After assessing the condition of the electrical power supply, Valero began the process of restarting the affected units late on 10/12/17. This continued until 10/15/17. Additionally, while loading a Hydrogen Make-Up Gas Compressor in the Middle Distillate Hydrogen Unit (MDH) at 20:12 on 10/14/17, the discharge PSV lifted and began passing pipeline Hydrogen to the North Flare, increasing the volume flared but having no effect on SO2 emissions. Valero was delayed in locating this source of flaring due to the MDH being connected to the South Flare and normally flaring on the South Flare, and this gas passing to the North Flare due to a low Flare Gas Recovery (FGR) Liquid Seal on the North Flare.

(2.) (60.108a(c)(6)(iii) and (60.108a(c)(6)(ix))

	Flaring	#3 SRU
Date and Time the discharge was first identified	<u>10/12/17 23:15</u>	<u>10/12/17 23:15</u>
Date/Time the discharge had ceased	<u>10/15/17 7:15</u>	<u>10/13/17 8:40</u>
Duration of Discharge (Calculated)	<u>56.0</u>	<u>9.4 hrs</u>

(3.) (60.108a(c)(6)(viii))

The steps taken to limit the emissions during the discharge:

Valero initiated it's refinery sulfur shedding procedure and followed its Flare Minimization Plan and Operations Procedures to minimize the volume and SO2 emissions of this discharge.

(4.) (60.108a(c)(6)(xi))

Necessity of RC/CAA: Determine and state whether a RC/CAA is necessary:

Note: If the discharge was a result of a planned startup or shutdown, a RC/CAA analysis is not required if the flare management plan was followed.

Did the discharge result from a planned startup or shutdown?	<u>No</u>	(Yes/No)
Was the flare management plan followed?	<u>Yes</u>	(Yes/No/N/A)
Is the event exempt from a RC/CCA based on the answers above?	<u>No</u>	(Yes/No)

- If yes, skip section 5-7.

(5.) (60.108a(c)(6)(ix))

Root Cause Analysis: Describe in detail the Root Cause(s) of the Incident, to the extent determinable:

Did this discharge result from root causes identified in a previous analysis? No (Yes/No)

The root cause of the power interruption was a flashover on a failed insulator on one of the electrical transmission lines powering the refinery and surrounding area. As this event occurred on 3rd-party equipment located several miles from the refinery, there are no corrective actions available to refinery personnel.

The root causes of the additional flaring from the MDH Make-Up Gas Compressor were:

1) Refinery personnel were searching for sources on the North Flare and not the South Flare. Both flares are connected at the suction of the FGR unit, but normally flaring has occurred on the flare that the source is most directly connected to. However, in this case the low FGR Liquid Seal presented the path of least resistance and a source on the South Flare passed to the North Flare. Refinery personnel were not generally aware that this crossflow was possible and this was the first time that this has been observed.

2) FGR unit inlet flowmeters were not reading properly. This would have assisted operations in locating the source of flaring.

3) MDH Make-Up Compressor discharge PSV lifted during loading and did not re-seat when pressure returned to normal.

(6.) (60.108a(c)(6)(ix))

Corrective Action Analysis: Include a description of the recommended corrective action(s) or an explanation of why corrective action is not Is corrective action required? Yes (Yes/No)

1) Develop Operation Learning Bulletin on locating sources of flaring and review with Operations.

2) Evaluate the suitability of the FGR inlet flow meters.

3) Review the MDH Unit Start-Up procedure for appropriate time for loading compressor.

4) Pull and Inspect the Compressor discharge PSV at next opportunity and evaluate test frequency.

(7.) (60.108a(c)(6)(x))

Corrective Action Schedule: Include corrective actions already completed within the first 45 days following the discharge. For those not completed, provide a schedule for implementation, including proposed commencement and completion dates.

1) Develop Operation Learning Bulletin on locating sources of flaring and review with Operations.

Commencement Date: 11/20/17

Completed Date: 2/19/18

2) Evaluate the suitability of the FGR inlet flow meters.

Commencement Date: 11/20/17

Completed Date: 2/14/18

3) Review the MDH Unit Start-Up procedure for appropriate time for loading compressor.

Commencement Date: 11/20/17

Completed Date: 1/30/18

4) Pull and Inspect the Compressor discharge PSV at next opportunity and evaluate test frequency.

Commencement Date: 11/20/17

Estimated Completion Date: 10/2/18

(8.) North and South Flares

The measured or calculated cumulative quantity of gas discharged over the discharge duration.

Note: Measured sulfur concentrations are shown as flow-weighted averages if multiple measurement devices were used.

		(60.108a(c)(6)(iii))	(60.108a(c)(6)(iv))	(60.108a(c)(6)(vii))	(60.108a(c)(6)(vii))
First hour of 24-hr Period	Last hour of 24-hr Period	24-hr cumulative volume of flared gas above Baseline	TRS or H2S ppm (24-hr average, flow-weighted)	24-hr cumulative SO2	24-hr cumulative reduced sulfur
		SCF	ppmv	lbs	lbs as H2S
10/11/17 23:00	10/12/17 22:00	79,804	2,181	28	0
10/12/17 0:00	10/12/17 23:00	556,987	2213	713.0	3.8
10/12/17 1:00	10/13/17 0:00	1,370,333	2426	1575.6	8.5
10/12/17 2:00	10/13/17 1:00	2,030,227	2496	2157.3	11.6
10/12/17 3:00	10/13/17 2:00	2,569,527	2615	2497.9	13.4
10/12/17 4:00	10/13/17 3:00	3,044,471	2745	2763.7	14.9
10/12/17 5:00	10/13/17 4:00	3,357,929	2804	2847.1	15.3
10/12/17 6:00	10/13/17 5:00	3,713,991	2904	3006.0	16.2
10/12/17 7:00	10/13/17 6:00	3,962,626	2642	3051.3	16.4
10/12/17 8:00	10/13/17 7:00	4,126,690	2504	3093.6	16.6
10/12/17 9:00	10/13/17 8:00	4,279,062	2507	3107.1	16.7
10/12/17 10:00	10/13/17 9:00	4,431,763	2517	3123.1	16.8
10/12/17 11:00	10/13/17 10:00	4,655,723	2530	3148.2	16.9
10/12/17 12:00	10/13/17 11:00	4,761,204	2541	3159.2	17.0
10/12/17 13:00	10/13/17 12:00	4,822,724	2556	3166.8	17.0
10/12/17 14:00	10/13/17 13:00	4,887,499	2568	3176.4	17.1
10/12/17 15:00	10/13/17 14:00	4,929,459	2578	3181.5	17.1
10/12/17 16:00	10/13/17 15:00	4,935,909	2580	3182.0	17.1
10/12/17 17:00	10/13/17 16:00	4,942,066	2586	3182.6	17.1
10/12/17 18:00	10/13/17 17:00	5,005,683	2593	3187.8	17.1
10/12/17 19:00	10/13/17 18:00	5,018,620	2564	3187.8	17.1
10/12/17 20:00	10/13/17 19:00	5,020,739	2387	3184.6	17.1
10/12/17 21:00	10/13/17 20:00	5,022,906	2235	3182.8	17.1
10/12/17 22:00	10/13/17 21:00	5,023,978	1985	3180.7	17.1
10/12/17 23:00	10/13/17 22:00	5,013,053	1918	3177.3	17.1
10/13/17 0:00	10/13/17 23:00	4,538,493	1555	2490.1	13.4
10/13/17 1:00	10/14/17 0:00	3,727,819	1293	1627.3	8.7
10/13/17 2:00	10/14/17 1:00	3,076,264	1077	1043.9	5.6
10/13/17 3:00	10/14/17 2:00	2,641,487	933	708.6	3.8
10/13/17 4:00	10/14/17 3:00	2,257,652	804	447.1	2.4
10/13/17 5:00	10/14/17 4:00	1,950,902	821	365.9	2.0
10/13/17 6:00	10/14/17 5:00	1,590,761	796	207.1	1.1
10/13/17 7:00	10/14/17 6:00	1,341,159	809	159.4	0.9
10/13/17 8:00	10/14/17 7:00	1,179,119	755	115.8	0.6
10/13/17 9:00	10/14/17 8:00	1,023,963	819	102.5	0.6
10/13/17 10:00	10/14/17 9:00	870,258	797	86.5	0.5
10/13/17 11:00	10/14/17 10:00	644,711	1004	61.6	0.3
10/13/17 12:00	10/14/17 11:00	538,414	987	50.5	0.3
10/13/17 13:00	10/14/17 12:00	479,508	965	42.9	0.2
10/13/17 14:00	10/14/17 13:00	416,143	936	33.2	0.2
10/13/17 15:00	10/14/17 14:00	372,832	917	27.9	0.1
10/13/17 16:00	10/14/17 15:00	370,041	905	27.4	0.1
10/13/17 17:00	10/14/17 16:00	369,642	893	27.0	0.1
10/13/17 18:00	10/14/17 17:00	306,458	882	21.7	0.1
10/13/17 19:00	10/14/17 18:00	289,707	880	21.0	0.1
10/13/17 20:00	10/14/17 19:00	287,065	886	21.1	0.1
10/13/17 21:00	10/14/17 20:00	382,596	756	22.0	0.1
10/13/17 22:00	10/14/17 21:00	523,446	716	27.9	0.1

(8.) North and South Flares cont.

The measured or calculated cumulative quantity of gas discharged over the discharge duration.

Note: Measured sulfur concentrations are shown as flow-weighted averages if multiple measurement devices were used.

		(60.108a(c)(6)(iii))	(60.108a(c)(6)(iv))	(60.108a(c)(6)(vii))	(60.108a(c)(6)(vii))
First hour of 24-hr Period	Last hour of 24-hr Period	24-hr cumulative volume of flared gas above Baseline	TRS or H2S ppm (24-hr average, flow-weighted)	24-hr cumulative SO2	24-hr cumulative reduced sulfur
		SCF	ppmv	lbs	lbs as H2S
10/13/17 23:00	10/14/17 22:00	666,165	729	35.1	0.2
10/14/17 0:00	10/14/17 23:00	746,398	743	39.9	0.2
10/14/17 1:00	10/15/17 0:00	793,002	751	42.8	0.2
10/14/17 2:00	10/15/17 1:00	837,473	775	49.1	0.3
10/14/17 3:00	10/15/17 2:00	729,010	772	43.0	0.2
10/14/17 4:00	10/15/17 3:00	638,115	761	38.6	0.2
10/14/17 5:00	10/15/17 4:00	632,643	679	36.3	0.2
10/14/17 6:00	10/15/17 5:00	671,569	593	36.2	0.2
10/14/17 7:00	10/15/17 6:00	729,056	539	37.6	0.2
10/14/17 8:00	10/15/17 7:00	735,319	540	37.9	0.2
10/14/17 9:00	10/15/17 8:00	733,951	464	37.3	0.2
10/14/17 10:00	10/15/17 9:00	740,787	470	37.5	0.2
10/14/17 11:00	10/15/17 10:00	751,739	245	37.7	0.2
10/14/17 12:00	10/15/17 11:00	752,383	246	37.7	0.2
10/14/17 13:00	10/15/17 12:00	750,985	246	37.7	0.2
10/14/17 14:00	10/15/17 13:00	754,828	247	37.8	0.2
10/14/17 15:00	10/15/17 14:00	752,406	246	37.7	0.2
10/14/17 16:00	10/15/17 15:00	748,801	245	37.6	0.2
10/14/17 17:00	10/15/17 16:00	743,389	244	37.4	0.2
10/14/17 18:00	10/15/17 17:00	742,007	241	37.3	0.2
10/14/17 19:00	10/15/17 18:00	744,422	235	37.3	0.2
10/14/17 20:00	10/15/17 19:00	745,108	227	37.2	0.2
10/14/17 21:00	10/15/17 20:00	646,907	219	32.4	0.2
10/14/17 22:00	10/15/17 21:00	506,614	212	25.8	0.1
10/14/17 23:00	10/15/17 22:00	363,791	206	18.7	0.1

(9.) #3 SRU

The measured or calculated cumulative quantity of gas discharged over the discharge duration.

Note: Measured sulfur concentrations are shown as flow-weighted averages if multiple measurement devices were used.

		(60.108a(c)(6)(iii))	(60.108a(c)(6)(vi))	(60.108a(c)(6)(vii))	(60.108a(c)(6)(vii))
First hour of 24-hr Period	Last hour of 24-hr Period	24-hr cumulative volume	SO ₂ ppm (24-hr average, flow-weighted) ¹	24-hr cumulative SO ₂ ²	24-hr cumulative reduced sulfur
		SCF	ppmv	lbs	lbs as H2S
10/11/17 23:00	10/12/17 22:00	26,160,801	61	265.7	1.4
10/12/17 0:00	10/12/17 23:00	25,713,844	78	309.4	1.7
10/12/17 1:00	10/13/17 0:00	25,016,353	110	349.0	1.9
10/12/17 2:00	10/13/17 1:00	24,388,653	148	408.7	2.2
10/12/17 3:00	10/13/17 2:00	23,756,876	188	470.0	2.5
10/12/17 4:00	10/13/17 3:00	23,103,815	217	512.7	2.8
10/12/17 5:00	10/13/17 4:00	22,489,649	220	512.0	2.8
10/12/17 6:00	10/13/17 5:00	22,399,688	245	609.2	3.3
10/12/17 7:00	10/13/17 6:00	22,464,459	284	786.0	4.2
10/12/17 8:00	10/13/17 7:00	22,404,515	300	850.0	4.6
10/12/17 9:00	10/13/17 8:00	22,384,394	304	864.6	4.6
10/12/17 10:00	10/13/17 9:00	21,985,042	306	865.2	4.7
10/12/17 11:00	10/13/17 10:00	21,503,107	307	862.8	4.6

(9.) #3 SRU cont.

The measured or calculated cumulative quantity of gas discharged over the discharge duration.

Note: Measured sulfur concentrations are shown as flow-weighted averages if multiple measurement devices were used.

		(60.108a(c)(6)(iii))	(60.108a(c)(6)(vi))	(60.108a(c)(6)(vii))	(60.108a(c)(6)(vii))
First hour of 24-hr Period	Last hour of 24-hr Period	24-hr cumulative volume	SO ₂ ppm	24-hr cumulative SO ₂ ²	24-hr cumulative reduced sulfur
			(24-hr average, flow-weighted) ¹		
		SCF	ppmv	lbs	lbs as H ₂ S
10/12/17 12:00	10/13/17 11:00	20,965,577	308	859.3	4.6
10/12/17 13:00	10/13/17 12:00	20,375,776	309	854.7	4.6
10/12/17 14:00	10/13/17 13:00	19,826,919	309	850.8	4.6
10/12/17 15:00	10/13/17 14:00	19,395,604	311	851.0	4.6
10/12/17 16:00	10/13/17 15:00	19,004,978	313	853.5	4.6
10/12/17 17:00	10/13/17 16:00	18,684,168	315	857.2	4.6
10/12/17 18:00	10/13/17 17:00	18,422,720	319	865.3	4.7
10/12/17 19:00	10/13/17 18:00	18,163,433	320	867.3	4.7
10/12/17 20:00	10/13/17 19:00	17,879,891	321	867.6	4.7
10/12/17 21:00	10/13/17 20:00	17,617,428	322	868.5	4.7
10/12/17 22:00	10/13/17 21:00	17,310,203	324	872.4	4.7
10/12/17 23:00	10/13/17 22:00	16,922,143	327	875.9	4.7
10/13/17 0:00	10/13/17 23:00	17,018,368	313	836.7	4.5
10/13/17 1:00	10/14/17 0:00	17,360,271	283	801.4	4.3
10/13/17 2:00	10/14/17 1:00	17,637,067	248	746.5	4.0
10/13/17 3:00	10/14/17 2:00	17,938,692	212	690.8	3.7
10/13/17 4:00	10/14/17 3:00	18,269,294	186	656.0	3.5
10/13/17 5:00	10/14/17 4:00	18,552,968	186	661.8	3.6
10/13/17 6:00	10/14/17 5:00	18,346,251	164	570.2	3.1
10/13/17 7:00	10/14/17 6:00	17,990,768	128	399.4	2.1

¹ SRU SO₂ CEMS are spanned to 500 ppm. For emissions calculations, Valero assumes 2 times the span, 1000 ppm, for CEMS readings >= 500 ppm.

² Tail Gas Treater bypass emissions are calculated using a mass balance method, not using the flow and concentration values listed here.

Subpart Ja Root Cause / Corrective Action AnalysisImpact Incident Number: **344894***The information contained below satisfies the requirements of the NSPS Subpart Ja 60.108a(c)(6).*

Report:	<u>Final</u>	Date of Event:	<u>12/13/17</u>
Refinery:	<u>Valero (Meraux)</u>	Date Analysis Completed:	<u>1/25/18</u>
Incident Type:	<u>Flaring (Flow)</u>		
Emissions Source(s):	<u>North Flare (EPN 20-72, EQT 0035)</u>		

(1.) (60.108a(c)(6)(i))

A description of the Discharge:

On 12/13/17 at 09:23, the Reformer Net Gas Compressor (NGC) tripped due to high seal gas vent pressure. The seal gas is supplied from an on-site Nitrogen facility that is owned and operated by a 3rd party. This Nitrogen facility was in a turnaround and the Nitrogen generator that is normally in service was not running, leaving the refinery completely dependent on liquid Nitrogen delivered by truck. A scheduled truck delivery was missed and the liquid Nitrogen tank level became low and the Nitrogen pressure was reduced. A few hours before the trip, manual valves for the NGC seal gas were throttled open further than normal after receiving a low flow alarm. When the truck arrived and began filling the Nitrogen tank, the pressure returned and caused the seal gas to trip on high pressure.

The compressor itself was quickly restarted at 09:25, but Valero had difficulty loading the compressor and stopping the flaring. The gas flared from this event caused flaring at the North Flare to exceed 500,000 SCF in a 24 hour period. This gas was pipeline quality Hydrogen, free of H2S or other Sulfur compounds.

(2.) (60.108a(c)(6)(ii)) and (60.108a(c)(6)(ix))

Date and Time the discharge was first identified	<u>12/13/17 9:23</u>
Date/Time the discharge had ceased	<u>12/13/17 10:59</u>
Duration of Discharge (Calculated)	<u>1.6</u> hrs

(3.) (60.108a(c)(6)(viii))

The steps taken to limit the emissions during the discharge:

Valero followed its Flare Minimization Plan and Operations Procedures to minimize the volume of this discharge.

(4.) (60.108a(c)(6)(xi))

Necessity of RC/CAA: Determine and state whether a RC/CAA is necessary:

Note: If the discharge was a result of a planned startup or shutdown, a RC/CAA analysis is not required if the flare management plan was followed.

Did the discharge result from a planned startup or shutdown?	<u>No</u>	(Yes/No)
Was the flare management plan followed?	<u>Yes</u>	(Yes/No/N/A)
Is the event exempt from a RC/CCA based on the answers above? - If yes, skip section 5-7.	<u>No</u>	(Yes/No)

(5.) (60.108a(c)(6)(ix))

Root Cause Analysis: Describe in detail the Root Cause(s) of the Incident, to the extent determinable:

Did this discharge result from root causes identified in a previous analysis? No (Yes/No)

Root Cause(s):

1) Low level in the refinery liquid Nitrogen tank. This was a manpower issue with the 3rd-party Nitrogen supplier and cannot be resolved by corrective actions by Valero personnel.

2) The delay in loading the NGC was due to not operating the anti-surge system as designed. Operations believed that the anti-surge system did not work and were attempting to load the compressor in partial-manual mode where anti-surge functions were overriding manual controls.

3) The procedure does not address the proper modes for the suction and spillback valves for loading the compressor.

(6.) (60.108a(c)(6)(ix))
Corrective Action Analysis: Include a description of the recommended corrective action(s) or an explanation of why corrective action is not Is corrective action required? Yes (Yes/No)
 1) Conduct a test run to identify issues with full automatic operation of the anti-surge system and correct any deficiencies noted.
 2) Based on the resolution of the anti-surge control scheme, revise the operating procedure to include the loading of the compressor.

(7.) (60.108a(c)(6)(x))
Corrective Action Schedule: Include corrective actions already completed within the first 45 days following the discharge. For those not completed, provide a schedule for implementation, including proposed commencement and completion dates.
 1) Conduct a test run to identify issues with full automatic operation of the anti-surge system and correct any deficiencies noted.
 Commencement Date: 1/25/18
 Completed Date: 1/31/18
 2) Based on the resolution of the anti-surge control scheme, revise the operating procedure to include the loading of the compressor.
 Commencement Date: 1/25/18
 Completed Date: 3/13/18

(8.)
The measured or calculated cumulative quantity of gas discharged over the discharge duration.
 Note: Measured sulfur concentrations are shown as flow-weighted averages if multiple measurement devices were used.

		(60.108a(c)(6)(iii))	(60.108a(c)(6)(iv))	(60.108a(c)(6)(vii))	(60.108a(c)(6)(viii))
First hour of 24-hr Period	Last hour of 24-hr Period	24-hr cumulative volume of flared gas above Baseline	TRS or H2S ppm (24-hr average, flow-weighted)	24-hr cumulative SO2	24-hr cumulative reduced sulfur
		SCF	ppmv	lbs	lbs as H2S
12/12/17 9:00	12/13/17 8:00	12,850	27	1.4	0.0
12/12/17 10:00	12/13/17 9:00	457,548	37	17.7	0.1
12/12/17 11:00	12/13/17 10:00	664,661	49	28.2	0.2
12/12/17 12:00	12/13/17 11:00	664,661	49	28.2	0.2
12/12/17 13:00	12/13/17 12:00	664,661	49	28.2	0.2
12/12/17 14:00	12/13/17 13:00	664,661	49	28.2	0.2
12/12/17 15:00	12/13/17 14:00	664,661	49	28.2	0.2
12/12/17 16:00	12/13/17 15:00	664,661	49	28.2	0.2
12/12/17 17:00	12/13/17 16:00	664,661	49	28.2	0.2
12/12/17 18:00	12/13/17 17:00	664,661	49	28.2	0.2
12/12/17 19:00	12/13/17 18:00	664,661	49	28.2	0.2
12/12/17 20:00	12/13/17 19:00	664,661	49	28.2	0.2
12/12/17 21:00	12/13/17 20:00	651,811	22	26.8	0.1
12/12/17 22:00	12/13/17 21:00	651,811	22	26.8	0.1
12/12/17 23:00	12/13/17 22:00	651,811	22	26.8	0.1
12/13/17 0:00	12/13/17 23:00	651,811	22	26.8	0.1
12/13/17 1:00	12/14/17 0:00	651,811	22	26.8	0.1
12/13/17 2:00	12/14/17 1:00	651,811	22	26.8	0.1
12/13/17 3:00	12/14/17 2:00	651,811	22	26.8	0.1
12/13/17 4:00	12/14/17 3:00	651,811	22	26.8	0.1
12/13/17 5:00	12/14/17 4:00	651,811	22	26.8	0.1
12/13/17 6:00	12/14/17 5:00	651,811	22	26.8	0.1
12/13/17 7:00	12/14/17 6:00	651,811	22	26.8	0.1
12/13/17 8:00	12/14/17 7:00	651,811	22	26.8	0.1
12/13/17 9:00	12/14/17 8:00	651,811	22	26.8	0.1
12/13/17 10:00	12/14/17 9:00	207,113	13	10.5	0.1
12/13/17 11:00	12/14/17 10:00	0	0	0.0	0.0

Subpart Ja Root Cause / Corrective Action Analysis

Incident Number: 345189/345193

The information contained below satisfies the requirements of the NSPS Subpart Ja 60.108a(c)(6).

Report: Initial
 Refinery: Valero (Meraux)
 Incident Type: Flaring (Flow and SO2), SRU (SO2)
 Emissions Source(s): North Flare (EPN 20-72, EQT 0035)
South Flare (EPN 3-77, EQT 0049)
#3 SRU Incinerator (EPN 5-00, EQT 0079)

Date of Event: 1/2/18
 Date Analysis Completed: 2/15/18

(1.) (60.108a(c)(6)(ii))

A description of the Discharge:

Beginning at approximately 07:00 on January 1, 2018, the Meraux Refinery began experiencing SO2 emissions caused by multiple instrumentation failures throughout the refinery due to exceptionally cold air temperatures (approximately 24 F). Intermittent SO2 emissions began on January 1 due to instability of the #3 Sulfur Recovery Unit (SRU) followed by the loss of the Flare Gas Recovery Unit compressor on January 2nd from 06:20-08:35. One of the refinery's two main boilers, Boiler B-5, tripped offline at 04:33 on January 2nd and could not be restarted. Later at 08:11 the remaining main boiler, Boiler B-6, tripped offline and caused a shortage of steam and reduced steam header pressures across the entire refinery. At 09:02, the Hydrocracker Unit (HCU) tripped offline and performed an automatic depressurization due to reduced flow from its steam driven Recycle Gas Compressor. The bulk of the SO2 emissions from flaring occurred during this depressurization event, and the resultant trip of the #3 SRU, which takes its feed from the HCU. The restart of the #3 SRU was also delayed by instrumentation failures, causing additional SO2 emissions.

(2.) (60.108a(c)(6)(ii) and (60.108a(c)(6)(ix))

	Flares	#3 SRU
Date and Time the discharge was first identified	<u>1/2/18 6:20</u>	<u>1/1/18 7:00</u>
Date/Time the discharge had ceased	<u>1/2/18 16:20</u>	<u>1/3/18 10:00</u>
Duration of Discharge (Calculated)	<u>10.0</u>	<u>51.0</u> hrs

(3.) (60.108a(c)(6)(viii))

The steps taken to limit the emissions during the discharge:

Valero initiated its refinery sulfur shedding procedure and followed its Flare Minimization Plan and Operations Procedures to minimize the volume and SO2 emissions of this discharge.

(4.) (60.108a(c)(6)(xi))

Necessity of RC/CAA: Determine and state whether a RC/CAA is necessary:

Note: If the discharge was a result of a planned startup or shutdown, a RC/CAA analysis is not required if the flare management plan was followed.

Did the discharge result from a planned startup or shutdown? No (Yes/No)
 Was the flare management plan followed? Yes (Yes/No/N/A)
 Is the event exempt from a RC/CAA based on the answers above? No (Yes/No)
 - If yes, skip section 5-7.

(5.) (60.108a(c)(6)(ix))

Root Cause Analysis: Describe in detail the Root Cause(s) of the Incident, to the extent determinable:

Did this discharge result from root causes identified in a previous analysis? No (Yes/No)

The root cause(s) of this incident were the cold weather or other instrumentation failures on Boiler B-5, Boiler B-6, and the #3 SRU as described below:

- 1) Boiler B-5
 - a) B-5 tripped on low fuel gas pressure. The fuel gas pressure regulator pilot filter is not free draining and its tubing is not protected from freezing. Liquids accumulated and froze and clogged the pilot filter.
 - b) B-5 could not be restarted due to slack in the linkages for switch feedback causing false position indications on the Flue Gas Recirculation Damper, Stack Damper, and Fresh Air Damper. The false position indications prevented start up permissives from being satisfied. These feedback switches were newly installed in 2017.
- 2) Boiler B-6
 - a) B-6 tripped on a false high steam pressure indication. This trip is provided by a single pressure instrument. The impulse lines for this instrument were not properly insulated and froze.
- 3) #3 SRU
 - a) The temperature of the analyzer probe for the Air Demand Analyzer got too low and caused the Air Demand Analyzer to indicate a fault. This fault prevents automatic operation of the SRU Main Burner combustion air and led to several trips of the Main Burner.
 - b) Several other critical instruments were not working properly due to frozen impulse lines.
 - c) Some purge gas rotameters on critical instruments were cracked during the freeze causing the loss of that instrument.

(6.)

(60.108a(c)(6)(ix))

Corrective Action Analysis: Include a description of the recommended corrective action(s) or an explanation of why corrective action is not necessary.

Is corrective action required? Yes (Yes/No)

- 1) *Re-pipe B-5 and B-6 fuel gas regulator pilot filters to eliminate the low point, add insulation and tracing, and install pressure gauges across pilot filters.*
- 2) *Add checking the fuel gas regulator pilot filter differential pressure to operator rounds.*
- 3) *Remove the newly installed feedback switches and replace them with the original ones that had better reliability.*
- 4) *Install additional steam pressure instruments to provide 2 out of 3 logic for the high steam pressure trip.*
- 5) *Add insulation and heat tracing to B-5 and B-6 steam pressure instruments.*
- 6) *Pull and inspect the #3 SRU Air Demand Analyzer probe and verify that it is installed correctly.*
- 7) *Develop a preventative maintenance schedule for the periodic replacement of purge gas rotameters in the SRUs.*
- 8) *Evaluate moving the #3 SRU Air Flowmeter to Tail Gas Burner transmitters above taps*
- 9) *Provide winterization protection for the affected instruments in the #3 SRU.*

(7.)

(60.108a(c)(6)(x))

Corrective Action Schedule: Include corrective actions already completed within the first 45 days following the discharge. For those not completed, provide a schedule for implementation, including proposed commencement and completion dates.

- 1) *Re-pipe B-5 and B-6 fuel gas regulator pilot filters to eliminate the low point, add insulation and tracing, and install pressure gauges across pilot filters.*

Commencement Date: 2/15/18

Estimated Completion Date: 10/30/18

- 2) *Add checking the fuel gas regulator pilot filter differential pressure to operator rounds.*

Commencement Date: 2/15/18

Estimated Completion Date: 11/13/18

- 3) *Remove the newly installed feedback switches and replace them with the original ones that had better reliability.*

Commencement Date: 2/15/18

Estimated Completion Date: 10/30/18

- 4) *Install additional steam pressure instruments to provide 2 out of 3 logic for the high steam pressure trip.*

Commencement Date: 2/15/18

Estimated Completion Date: 10/30/18

- 5) *Add insulation and heat tracing to B-5 and B-6 steam pressure instruments.*

Commencement Date: 2/15/18

Estimated Completion Date: 10/30/18

- 6) *Pull and inspect the #3 SRU Air Demand Analyzer probe and verify that it is installed correctly.*

Commencement Date: 2/15/18

Estimated Completion Date: 10/30/18

- 7) *Develop a preventative maintenance schedule for the periodic replacement of purge gas rotameters in the SRUs.*

Commencement Date: 2/15/18

Completed Date: 4/3/18

- 8) *Evaluate moving the #3 SRU Air Flowmeter to Tail Gas Burner transmitters above taps*

Commencement Date: 2/15/18

Completed Date: 4/17/18

- 9) *Provide winterization protection for the affected instruments in the #3 SRU.*

Commencement Date: 2/15/18

Completion Date: 9/25/18

(8.) North and South Flares

The measured or calculated cumulative quantity of gas discharged over the discharge duration.

Note: Measured sulfur concentrations are shown as flow-weighted averages if multiple measurement devices were used.

		(60.108a(c)(6)(iii))	(60.108a(c)(6)(iv))	(60.108a(c)(6)(vii))	(60.108a(c)(6)(vii))
First hour of 24-hr Period	Last hour of 24-hr Period	24-hr cumulative volume of flared gas above Baseline	TRS or H2S ppm (24-hr average, flow-weighted)	24-hr cumulative SO2	24-hr cumulative reduced sulfur
		SCF	ppmv	lbs	lbs as H2S
1/1/18 9:00	1/2/18 8:00	385,450	27	12.4	0.1
1/1/18 10:00	1/2/18 9:00	759,797	65	67.3	0.4
1/1/18 11:00	1/2/18 10:00	962,465	390	327.7	1.8
1/1/18 12:00	1/2/18 11:00	1,174,431	490	411.4	2.2
1/1/18 13:00	1/2/18 12:00	1,174,431	490	411.4	2.2
1/1/18 14:00	1/2/18 13:00	1,174,431	490	411.4	2.2
1/1/18 15:00	1/2/18 14:00	1,174,431	490	411.4	2.2
1/1/18 16:00	1/2/18 15:00	1,186,246	527	413.2	2.2
1/1/18 17:00	1/2/18 16:00	1,187,174	555	413.3	2.2
1/1/18 18:00	1/2/18 17:00	1,187,174	555	413.3	2.2
1/1/18 19:00	1/2/18 18:00	1,187,174	555	413.3	2.2
1/1/18 20:00	1/2/18 19:00	1,187,174	555	413.3	2.2
1/1/18 21:00	1/2/18 20:00	1,187,174	555	413.3	2.2
1/1/18 22:00	1/2/18 21:00	1,187,174	555	413.3	2.2
1/1/18 23:00	1/2/18 22:00	1,191,686	559	413.4	2.2
1/2/18 0:00	1/2/18 23:00	1,192,796	570	413.4	2.2
1/2/18 1:00	1/3/18 0:00	1,192,796	570	413.4	2.2
1/2/18 2:00	1/3/18 1:00	1,192,796	570	413.4	2.2
1/2/18 3:00	1/3/18 2:00	1,192,796	570	413.4	2.2
1/2/18 4:00	1/3/18 3:00	1,192,796	570	413.4	2.2
1/2/18 5:00	1/3/18 4:00	1,192,796	570	413.4	2.2
1/2/18 6:00	1/3/18 5:00	1,192,796	570	413.4	2.2
1/2/18 7:00	1/3/18 6:00	1,134,034	557	410.3	2.2
1/2/18 8:00	1/3/18 7:00	984,955	551	406.9	2.2
1/2/18 9:00	1/3/18 8:00	807,346	543	401.0	2.2
1/2/18 10:00	1/3/18 9:00	432,999	505	346.1	1.9
1/2/18 11:00	1/3/18 10:00	230,330	180	85.7	0.5

(9.) #3 SRU

The measured or calculated cumulative quantity of gas discharged over the discharge duration.

Note: Measured sulfur concentrations are shown as flow-weighted averages if multiple measurement devices were used.

		(60.108a(c)(6)(iii))	(60.108a(c)(6)(vi))	(60.108a(c)(6)(vii))	(60.108a(c)(6)(vii))
First hour of 24-hr Period	Last hour of 24-hr Period	24-hr cumulative volume	SO2 ppm (24-hr average, flow-weighted) ¹	24-hr cumulative SO2 above allowable ²	24-hr cumulative reduced sulfur above allowable
		SCF	ppmv	lbs	lbs as H2S
1/2/18 7:00	1/3/18 6:00	559,815	964	485.4	2.6
1/2/18 8:00	1/3/18 7:00	561,818	1000	554.8	3.0
1/2/18 9:00	1/3/18 8:00	576,345	1000	620.8	3.3
1/2/18 10:00	1/3/18 9:00	569,923	817	604.5	3.2
1/2/18 11:00	1/3/18 10:00	506,300	158	573.9	3.1
1/2/18 12:00	1/3/18 11:00	491,990	57	547.9	2.9
1/2/18 13:00	1/3/18 12:00	521,233	39	521.0	2.8
1/2/18 14:00	1/3/18 13:00	596,520	40	496.4	2.7
1/2/18 15:00	1/3/18 14:00	570,301	32	477.0	2.6

¹ SRU SO2 CEMS are spanned to 500 ppm. For emissions calculations, Valero assumes 2 times the span, 1000 ppm, for CEMS readings >= 500 ppm.

² Tail Gas Treater bypass emissions are calculated using a mass balance method, not using the flow and concentration values listed here.

Subpart Ja Root Cause / Corrective Action AnalysisIncident Number: **345418***The information contained below satisfies the requirements of the NSPS Subpart Ja 60.108a(c)(6).*

Report: Initial
 Refinery: Valero (Meraux)
 Incident Type: Flaring (Flow)
 Emissions Source(s): North Flare (EPN 20-72, EQT 0035)
South Flare (EPN 3-77, EQT 0049)

Date of Event: 1/15/18
 Date Analysis Completed: 3/1/18

(1.) (60.108a(c)(6)(i))**A description of the Discharge:**

On 1/15/18 at 16:52 the running Flare Gas Recovery (FGR) Compressor shutdown on low suction pressure due to plugging of its inlet cone strainer. The FGR Unit at the Meraux Refinery has two compressors, however the other compressor had been recently shutdown because of high differential pressure (dP) across its own inlet cone strainer. Valero was unable to quickly restart either compressor because of the plugged inlet strainers. Removing and cleaning the inlet cone strainers is a time consuming and complicated maintenance job involving the erection of scaffolding, purging of equipment, breaking flanges, and safety precautions to prevent worker exposure to hazardous gases. The inlet cone strainer was cleaned and the originally running FGR Compressor was started on 1/16/18 at 04:07.

(2.) (60.108a(c)(6)(ii) and (60.108a(c)(6)(ix))

	Flares
Date and Time the discharge was first identified	<u>1/15/18 16:52</u>
Date/Time the discharge had ceased	<u>1/16/18 4:18</u>
Duration of Discharge (Calculated)	<u>11.4</u>

(3.) (60.108a(c)(6)(viii))**The steps taken to limit the emissions during the discharge:**

Valero expedited the removal and cleaning of the inlet cone strainer and followed its Flare Minimization Plan and Operations Procedures to minimize the volume and SO2 emissions of this discharge.

(4.) (60.108a(c)(6)(xi))**Necessity of RC/CAA: Determine and state whether a RC/CAA is necessary:**

Note: If the discharge was a result of a planned startup or shutdown, a RC/CAA analysis is not required if the flare management plan was followed.

Did the discharge result from a planned startup or shutdown?	<u>No</u>	(Yes/No)
Was the flare management plan followed?	<u>Yes</u>	(Yes/No/N/A)
Is the event exempt from a RC/CCA based on the answers above?	<u>No</u>	(Yes/No)

- If yes, skip section 5-7.

(5.) (60.108a(c)(6)(ix))**Root Cause Analysis: Describe in detail the Root Cause(s) of the Incident, to the extent determinable:**

Did this discharge result from root causes identified in a previous analysis? No (Yes/No)

When the FGR Unit was in the design phase, Valero predicted the difficulties of cleaning these inlet cone strainers and installed a duplex strainer upstream of the inlet cone strainers for both machines. The duplex strainer is capable of being swapped and cleaned online and is easily accessible. A finer mesh filter material was also installed in the duplex strainer in the theory that it would make the need to clean the inlet cone strainers an infrequent event. Consequently, the instrumentation and alarms were implemented primarily on the duplex strainer and not the inlet cone strainers. However, due to the duplex strainer being significantly larger in surface area than the inlet cone strainers, and in spite of the duplex having a finer mesh, the inlet cone strainers were plugging more frequently than the duplex.

The investigation identified the root causes of this event to be:

- 1) There were no alarms for high inlet cone strainer dP.
- 2) There was no procedural guidance as to what inlet cone dP the compressor should be shutdown and cleaned.
- 3) The inlet cone strainer may not have been cleaned effectively the prior to the incident.

(6.)

(60.108a(c)(6)(ix))

Corrective Action Analysis: Include a description of the recommended corrective action(s) or an explanation of why corrective action is not Is corrective action required? Yes (Yes/No)

- 1) Evaluate the need for the both the duplex and the inlet cone strainers at the FGR compressors with the manufacturer. If not needed, eliminate the inlet cone strainers.
- 2) Implement alarms on the dP across inlet cone strainer. Evaluate a rate of change alarm on the dP.
- 3) Evaluate a dP value where the compressor should be shutdown and the intel cone strainer cleaned.
- 4) Outline the cleaning steps for the FGR strainers, both duplex and inlet cone.
- 5) Purchase a spare inlet cone strainer basket to reduce compressor downtime due to cleaning.

(7.)

(60.108a(c)(6)(x))

Corrective Action Schedule: Include corrective actions already completed within the first 45 days following the discharge. For those not completed, provide a schedule for implementation, including proposed commencement and completion dates.

- 1) Evaluate the need for the both the duplex and the inlet cone strainers at the FGR compressors with the manufacturer. If not needed, eliminate the inlet cone strainers.
Commencement Date: 3/1/18
Estimated Completion Date: 5/1/18
- 2) Implement alarms on the dP across inlet cone strainer. Evaluate a rate of change alarm on the dP.
Commencement Date: 3/1/18
Estimated Completion Date: 6/5/18
- 3) Evaluate a dP value where the compressor should be shutdown and the inlet cone strainer cleaned.
Commencement Date: 3/1/18
Estimated Completion Date: 6/5/18
- 4) Outline the cleaning steps for the FGR strainers, both duplex and inlet cone.
Commencement Date: 3/1/18
Estimated Completion Date: 7/3/18
- 5) Purchase a spare inlet cone strainer basket to reduce compressor downtime due to cleaning.
Commencement Date: 3/1/18
Estimated Completion Date: 7/3/18

(8.) North and South Flares

The measured or calculated cumulative quantity of gas discharged over the discharge duration.

Note: Measured sulfur concentrations are shown as flow-weighted averages if multiple measurement devices were used.

		(60.108a(c)(6)(iii))	(60.108a(c)(6)(iv))	(60.108a(c)(6)(vii))	(60.108a(c)(6)(vii))
First hour of 24-hr Period	Last hour of 24-hr Period	24-hr cumulative volume of flared gas above Baseline	TRS or H2S ppm (24-hr average, flow-weighted)	24-hr cumulative SO2	24-hr cumulative reduced sulfur
		SCF	ppmv	lbs	lbs as H2S
1/14/18 17:00	1/15/18 16:00	14,921	22	1	0
1/14/18 18:00	1/15/18 17:00	116,062	22	1.4	0.0
1/14/18 19:00	1/15/18 18:00	224,454	23	1.6	0.0
1/14/18 20:00	1/15/18 19:00	309,418	23	1.7	0.0
1/14/18 21:00	1/15/18 20:00	433,722	24	1.8	0.0
1/14/18 22:00	1/15/18 21:00	549,223	24	2.2	0.0
1/14/18 23:00	1/15/18 22:00	647,830	24	2.2	0.0
1/15/18 0:00	1/15/18 23:00	756,912	25	2.7	0.0
1/15/18 1:00	1/16/18 0:00	842,771	26	2.7	0.0
1/15/18 2:00	1/16/18 1:00	945,866	26	2.9	0.0
1/15/18 3:00	1/16/18 2:00	1,045,482	27	3.1	0.0
1/15/18 4:00	1/16/18 3:00	1,137,318	27	3.4	0.0
1/15/18 5:00	1/16/18 4:00	1,165,626	28	3.5	0.0
1/15/18 6:00	1/16/18 5:00	1,165,626	28	3.5	0.0
1/15/18 7:00	1/16/18 6:00	1,165,626	28	3.5	0.0
1/15/18 8:00	1/16/18 7:00	1,165,626	28	3.5	0.0
1/15/18 9:00	1/16/18 8:00	1,165,626	28	3.5	0.0
1/15/18 10:00	1/16/18 9:00	1,165,626	28	3.5	0.0
1/15/18 11:00	1/16/18 10:00	1,165,626	28	3.5	0.0
1/15/18 12:00	1/16/18 11:00	1,165,588	28	3.5	0.0
1/15/18 13:00	1/16/18 12:00	1,165,588	28	3.5	0.0
1/15/18 14:00	1/16/18 13:00	1,165,588	28	3.5	0.0
1/15/18 15:00	1/16/18 14:00	1,165,588	28	3.5	0.0
1/15/18 16:00	1/16/18 15:00	1,165,588	28	3.5	0.0
1/15/18 17:00	1/16/18 16:00	1,150,705	6	2.2	0.0
1/15/18 18:00	1/16/18 17:00	1,049,564	5	2.1	0.0
1/15/18 19:00	1/16/18 18:00	941,172	5	1.9	0.0
1/15/18 20:00	1/16/18 19:00	856,208	5	1.8	0.0
1/15/18 21:00	1/16/18 20:00	731,904	4	1.6	0.0
1/15/18 22:00	1/16/18 21:00	622,901	315	9.3	0.0

Note: Another event requiring a Root Cause and Corrective Action Analysis began on 1/16/18 at 21:14.

Subpart Ja Root Cause / Corrective Action Analysis

Incident Number: 350366

The information contained below satisfies the requirements of the NSPS Subpart Ja 60.108a(c)(6).

Report: Initial
 Refinery: Valero (Meraux)
 Incident Type: Flaring (Flow and SO2), SRU (SO2)
 Emissions Source(s): North Flare (EPN 20-72, EQT 0035)
South Flare (EPN 3-77, EQT 0049)
#2 SRU Incinerator (EPN 1-93, EQT 0019)
#3 SRU Incinerator (EPN 5-00, EQT 0079)

Date of Event: 1/16/18
 Date Analysis Completed: 3/1/18

(1.) (60.108a(c)(6)(i))

A description of the Discharge:

On January 16, 2018 at 21:15, the Meraux Refinery (Valero) and much of the surrounding area lost all electrical power. On the evening of January 16, 2018 a winter weather front moved into SE Louisiana that was unusual for the region, with 15-20 mph winds and freezing rain. Several 230kv power lines developed ice on the lines. The ice on the lines, combined with the wind, created ideal conditions for a phenomenon known as power line "galloping". At 21:05, the first of the two 230kv power lines feeding the refinery and surrounding area tripped and locked out. At 21:15, the second one tripped and locked out, resulting in a total loss of power to the Meraux Refinery. Power was not restored to the Meraux Refinery until the next morning at 09:20.

The loss of the electrical power also shutdown many of the instruments used to quantify emissions from the flares and Sulfur Recovery Units (SRU's). Even after the power was restored many of these instruments were damaged by the freezing conditions or required manual start ups by instrument technicians. The flare flowmeters were restored as soon as the power was restored (09:20), but the Total Sulfur analyzers were not online until approximately 17:00. In the period that the instruments were not available, Valero estimates that approximately 11,725 lbs of SO2 and 56.6 pounds of H2S were released from the combustion of >10,000,000 SCF of process upset gas in the flares. The estimates are based on similar upsets where the instruments were available. The SRU's were shutdown completely by the power loss and did not produce quantifiable emissions until late when the burners were re-lit and flow was re-established in the units. The data presented below starts after power was restored and the required instruments were back in service. By 17:00 on 1/17/18, the flaring from the power failure had subsided but flaring continued for several days at essentially baseline rates until the Flare Gas Recovery Unit could be placed in service. Valero used an alternate baseline during this period.

(2.) (60.108a(c)(6)(ii)) and (60.108a(c)(6)(ix))

	North Flare	#2 SRU	#3 SRU
Date/Time discharge was first identified	<u>1/17/18 9:00</u>	<u>1/19/18 3:15</u>	<u>1/19/18 1:35</u>
Date/Time discharge had ceased	<u>1/23/18 7:00</u>	<u>1/24/18 0:00</u>	<u>1/22/18 3:06</u>
Duration of Discharge (Calculated)	<u>142.0</u>	<u>116.8</u>	<u>73.5 hrs</u>

(3.) (60.108a(c)(6)(viii))

The steps taken to limit the emissions during the discharge:

Valero followed its Flare Minimization Plan and Operations Procedures to the maximum extent possible, given that no electrical power was available, to minimize the volume and SO2 emissions of this discharge

(4.) (60.108a(c)(6)(xi))

Necessity of RC/CAA: Determine and state whether a RC/CAA is necessary:

Note: If the discharge was a result of a planned startup or shutdown, a RC/CAA analysis is not required if the flare management plan was followed.

Did the discharge result from a planned startup or shutdown? No (Yes/No)
 Was the flare management plan followed? Yes (Yes/No/N/A)
 Is the event exempt from a RC/CCA based on the answers above? No (Yes/No)
 - If yes, skip section 5-7.

(5.) (60.108a(c)(6)(ix))

Root Cause Analysis: Describe in detail the Root Cause(s) of the Incident, to the extent determinable:

Did this discharge result from root causes identified in a previous analysis? No (Yes/No)

The root cause of this event was the loss of both main electrical feeds to the area due to "galloping" lines. As this event occurred on 3rd-party equipment located several miles from the refinery, there are no corrective actions available to refinery personnel. However, Valero has decided to research options for providing staged temporary power generators during inclement winter weather conditions for boilers and critical instrumentation and controls. This will not prevent a sudden loss of all power from causing an emissions release, but it will help prevent the freeze damage that Valero experienced from causing later releases during unit start ups.

(6.)

(60.108a(c)(6)(ix))

Corrective Action Analysis: Include a description of the recommended corrective action(s) or an explanation of why corrective action is not necessary.

Is corrective action required? Yes (Yes/No)

- 1) Evaluate temporary power generators staged for Boilers and the Control Room during winter conditions.
- 2) Establish periodic meeting with the electrical power provider to review power reliability.

(7.)

(60.108a(c)(6)(x))

Corrective Action Schedule: Include corrective actions already completed within the first 45 days following the discharge. For those not completed, provide a schedule for implementation, including proposed commencement and completion dates.

- 1) Evaluate temporary power generators staged for Boilers and the Control Room during winter conditions.

Commencement Date: 3/1/18

Estimated Completion Date: 10/30/18

- 2) Establish periodic meeting with the electrical power provider to review power reliability.

Commencement Date: 2/15/18

Completed Date: 3/21/18

(8.) North and South Flares

The measured or calculated cumulative quantity of gas discharged over the discharge duration.

Note: Measured sulfur concentrations are shown as flow-weighted averages if multiple measurement devices were used.

		(60.108a(c)(6)(iii))	(60.108a(c)(6)(iv))	(60.108a(c)(6)(vii))	(60.108a(c)(6)(vii))
First hour of 24-hr Period	Last hour of 24-hr Period	24-hr cumulative volume of flared gas above Baseline	TRS or H2S ppm (24-hr average, flow-weighted)	24-hr cumulative SO2	24-hr cumulative reduced sulfur
		SCF	ppmv	lbs	lbs as H2S
1/17/18 9:00	1/18/18 8:00	5,194,145			
1/17/18 10:00	1/18/18 9:00	5,314,303			
1/17/18 11:00	1/18/18 10:00	4,737,700			
1/17/18 12:00	1/18/18 11:00	4,046,831			
1/17/18 13:00	1/18/18 12:00	3,542,960			
1/17/18 14:00	1/18/18 13:00	3,054,971			
1/17/18 15:00	1/18/18 14:00	2,569,841			
1/17/18 16:00	1/18/18 15:00	2,050,583			
1/17/18 17:00	1/18/18 16:00	1,912,227	399	110.2	0.6
1/17/18 18:00	1/18/18 17:00	1,955,420	370	115.6	0.6
1/17/18 19:00	1/18/18 18:00	1,976,443	398	127.2	0.7
1/17/18 20:00	1/18/18 19:00	1,973,506	440	138.3	0.7
1/17/18 21:00	1/18/18 20:00	1,967,743	512	158.4	0.9
1/17/18 22:00	1/18/18 21:00	1,960,167	548	167.9	0.9
1/17/18 23:00	1/18/18 22:00	1,953,153	573	174.3	0.9
1/18/18 0:00	1/18/18 23:00	1,945,496	592	179.0	1.0
1/18/18 1:00	1/19/18 0:00	1,940,830	610	183.9	1.0
1/18/18 2:00	1/19/18 1:00	1,936,208	629	188.9	1.0
1/18/18 3:00	1/19/18 2:00	1,929,341	653	195.7	1.1
1/18/18 4:00	1/19/18 3:00	1,923,388	677	202.7	1.1
1/18/18 5:00	1/19/18 4:00	1,920,131	699	209.1	1.1
1/18/18 6:00	1/19/18 5:00	1,918,789	729	217.5	1.2
1/18/18 7:00	1/19/18 6:00	1,907,767	753	224.1	1.2
1/18/18 8:00	1/19/18 7:00	1,900,551	776	230.3	1.2
1/18/18 9:00	1/19/18 8:00	1,907,054	845	253.3	1.4
1/18/18 10:00	1/19/18 9:00	1,848,026	904	270.5	1.5
1/18/18 11:00	1/19/18 10:00	1,823,686	929	276.5	1.5
1/18/18 12:00	1/19/18 11:00	1,826,859	936	278.9	1.5
1/18/18 13:00	1/19/18 12:00	1,822,655	951	282.8	1.5
1/18/18 14:00	1/19/18 13:00	1,813,481	951	282.1	1.5
1/18/18 15:00	1/19/18 14:00	1,797,976	961	284.1	1.5
1/18/18 16:00	1/19/18 15:00	1,760,799	969	285.2	1.5
1/18/18 17:00 ¹	1/19/18 16:00	67,089	607	174.6	0.9
1/18/18 18:00	1/19/18 17:00	45,966	570	161.3	0.9
1/18/18 19:00	1/19/18 18:00	43,147	521	146.3	0.8
1/18/18 20:00	1/19/18 19:00	42,585	472	132.8	0.7
1/18/18 21:00	1/19/18 20:00	42,180	436	122.1	0.7
1/18/18 22:00	1/19/18 21:00	41,780	416	115.9	0.6
1/18/18 23:00	1/19/18 22:00	42,498	397	110.5	0.6
1/19/18 0:00	1/19/18 23:00	83,648	382	107.7	0.6
1/19/18 1:00	1/20/18 0:00	112,317	371	105.6	0.6
1/19/18 2:00	1/20/18 1:00	121,062	363	103.6	0.6
1/19/18 3:00	1/20/18 2:00	140,302	354	101.2	0.5
1/19/18 4:00	1/20/18 3:00	165,243	345	99.0	0.5
1/19/18 5:00	1/20/18 4:00	181,802	340	97.8	0.5
1/19/18 6:00	1/20/18 5:00	190,925	335	96.0	0.5

¹ Alternate Baseline established.

(9.) #2 SRU

The measured or calculated cumulative quantity of gas discharged over the discharge duration.

Note: Measured sulfur concentrations are shown as flow-weighted averages if multiple measurement devices were used.

		(60.108a(c)(6)(iii))	(60.108a(c)(6)(vi))	(60.108a(c)(6)(vii))	(60.108a(c)(6)(vii))
First hour of 24-hr Period	Last hour of 24-hr Period	24-hr cumulative volume	SO ₂ ppm (24-hr average, flow-weighted) ¹	24-hr cumulative SO ₂ above allowable ²	24-hr cumulative reduced sulfur above allowable
		SCF	ppmv	lbs	lbs as H ₂ S
1/22/18 12:00	1/23/18 11:00	133,309	1000	495.4	2.7
1/22/18 13:00	1/23/18 12:00	133,948	1000	505.0	2.7
1/22/18 14:00	1/23/18 13:00	133,558	1000	514.6	2.8
1/22/18 15:00	1/23/18 14:00	132,713	1000	520.3	2.8
1/22/18 16:00	1/23/18 15:00	131,226	1000	521.7	2.8
1/22/18 17:00	1/23/18 16:00	132,689	1000	521.5	2.8
1/22/18 18:00	1/23/18 17:00	132,549	1000	520.8	2.8
1/22/18 19:00	1/23/18 18:00	132,627	1000	520.2	2.8
1/22/18 20:00	1/23/18 19:00	133,228	1000	519.7	2.8
1/22/18 21:00	1/23/18 20:00	129,856	1000	519.0	2.8
1/22/18 22:00	1/23/18 21:00	129,034	1000	518.5	2.8
1/22/18 23:00	1/23/18 22:00	128,937	1000	517.9	2.8
1/23/18 0:00	1/23/18 23:00	129,798	978	516.5	2.8
1/23/18 1:00	1/24/18 0:00	120,020	99	494.8	2.7
1/23/18 2:00	1/24/18 1:00	120,997	70	473.0	2.5

¹ SRU SO₂ CEMS are spanned to 500 ppm. For emissions calculations, Valero assumes 2 times the span, 1000 ppm, for CEMS readings >= 500 ppm.

² Tail Gas Treater bypass emissions are calculated using a mass balance method, not using the flow and concentration values listed here.

(10.) #3 SRU

The measured or calculated cumulative quantity of gas discharged over the discharge duration.

Note: Measured sulfur concentrations are shown as flow-weighted averages if multiple measurement devices were used.

		(60.108a(c)(6)(iii))	(60.108a(c)(6)(vi))	(60.108a(c)(6)(vii))	(60.108a(c)(6)(vii))
First hour of 24-hr Period	Last hour of 24-hr Period	24-hr cumulative volume	SO ₂ ppm (24-hr average, flow-weighted) ¹	24-hr cumulative SO ₂ above allowable ²	24-hr cumulative reduced sulfur above allowable
		SCF	ppmv	lbs	lbs as H ₂ S
1/20/18 12:00	1/21/18 11:00	228,007	1000	494.2	2.7
1/20/18 13:00	1/21/18 12:00	228,441	1000	522.4	2.8
1/20/18 14:00	1/21/18 13:00	227,456	1000	550.5	3.0
1/20/18 15:00	1/21/18 14:00	252,617	1000	581.6	3.1
1/20/18 16:00	1/21/18 15:00	248,237	1000	612.3	3.3
1/20/18 17:00	1/21/18 16:00	237,833	1000	641.6	3.4
1/20/18 18:00	1/21/18 17:00	251,359	1000	672.0	3.6
1/20/18 19:00	1/21/18 18:00	250,865	1000	698.8	3.8
1/20/18 20:00	1/21/18 19:00	252,252	1000	702.4	3.8
1/20/18 21:00	1/21/18 20:00	252,051	1000	705.3	3.8
1/20/18 22:00	1/21/18 21:00	252,014	1000	708.0	3.8
1/20/18 23:00	1/21/18 22:00	252,955	1000	710.6	3.8
1/21/18 0:00	1/21/18 23:00	253,985	1000	713.2	3.8
1/21/18 1:00	1/22/18 0:00	253,629	1000	715.7	3.8
1/21/18 2:00	1/22/18 1:00	252,259	976	716.7	3.9
1/21/18 3:00	1/22/18 2:00	233,935	452	696.2	3.7
1/21/18 4:00	1/22/18 3:00	238,776	100	665.6	3.6
1/21/18 5:00	1/22/18 4:00	242,787	59	635.6	3.4
1/21/18 6:00	1/22/18 5:00	224,976	47	606.7	3.3
1/21/18 7:00	1/22/18 6:00	224,838	33	577.7	3.1
1/21/18 8:00	1/22/18 7:00	224,366	33	548.7	2.9
1/21/18 9:00	1/22/18 8:00	227,553	28	519.9	2.8
1/21/18 10:00	1/22/18 9:00	231,970	25	491.4	2.6
1/21/18 11:00	1/22/18 10:00	230,615	26	463.1	2.5

¹ SRU SO₂ CEMS are spanned to 500 ppm. For emissions calculations, Valero assumes 2 times the span, 1000 ppm, for CEMS readings >= 500 ppm.

² Tail Gas Treater bypass emissions are calculated using a mass balance method, not using the flow and concentration values listed here.

Subpart Ja Root Cause / Corrective Action AnalysisIncident Number: N/A*The information contained below satisfies the requirements of the NSPS Subpart Ja 60.108a(c)(6).*

Report: Final
 Refinery: Valero (Meraux)
 Incident Type: Flaring (Flow)
 Emissions Source(s): North Flare (EPN 20-72, EQT 0035)
South Flare (EPN 3-77, EQT 0049)

Date of Event: 1/24/18
 Date Analysis Completed: N/A

(1.) (60.108a(c)(6)(i))**A description of the Discharge:***Flaring due to multiple unit start ups after the total power failure on 1/16/18.***(2.)** (60.108a(c)(6)(ii) and (60.108a(c)(6)(ix))

Date and Time the discharge was first identified 1/24/18 11:26
 Date/Time the discharge had ceased 1/26/18 18:00
 Duration of Discharge (Calculated) 54.6 hrs

(3.) (60.108a(c)(6)(viii))**The steps taken to limit the emissions during the discharge:***Valero followed its Flare Minimization Plan and Operations Procedures to minimize the volume of this discharge.***(4.)** (60.108a(c)(6)(xi))**Necessity of RC/CAA: Determine and state whether a RC/CAA is necessary:***Note: If the discharge was a result of a planned startup or shutdown, a RC/CAA analysis is not required if the flare management plan was followed.*

Did the discharge result from a planned startup or shutdown? Yes (Yes/No)
 Was the flare management plan followed? Yes (Yes/No/N/A)
 Is the event exempt from a RC/CCA based on the answers above? Yes (Yes/No)
 - If yes, skip section 5-7.

(5.) (60.108a(c)(6)(ix))**Root Cause Analysis: Describe in detail the Root Cause(s) of the Incident, to the extent determinable:**

Did this discharge result from root causes identified in a previous analysis? No (Yes/No)
 N/A

(6.) (60.108a(c)(6)(ix))**Corrective Action Analysis: Include a description of the recommended corrective action(s) or an explanation of why corrective action is not**

Is corrective action required? No (Yes/No)
 N/A

(7.) (60.108a(c)(6)(x))**Corrective Action Schedule: Include corrective actions already completed within the first 45 days following the discharge. For those not completed, provide a schedule for implementation, including proposed commencement and completion dates.**

N/A

(8.)

The measured or calculated cumulative quantity of gas discharged over the discharge duration.

Note: Measured sulfur concentrations are shown as flow-weighted averages if multiple measurement devices were used.

	(60.108a(c)(6)(iii))	(60.108a(c)(6)(iv))	(60.108a(c)(6)(vii))	(60.108a(c)(6)(vii))	
First hour of 24-hr Period	Last hour of 24-hr Period	24-hr cumulative volume of flared gas above Baseline	TRS or H2S ppm (24-hr average, flow-weighted)	24-hr cumulative SO2	24-hr cumulative reduced sulfur
		SCF	ppmv	lbs	lbs as H2S
1/23/18 11:00	1/24/18 10:00	212,892	164	20.2	0.1
1/23/18 12:00	1/24/18 11:00	267,561	174	22.2	0.1
1/23/18 13:00	1/24/18 12:00	358,595	179	24.0	0.1
1/23/18 14:00	1/24/18 13:00	463,907	183	25.8	0.1
1/23/18 15:00	1/24/18 14:00	524,492	186	26.5	0.1
1/23/18 16:00	1/24/18 15:00	548,828	178	26.5	0.1
1/23/18 17:00	1/24/18 16:00	546,841	157	26.1	0.1
1/23/18 18:00	1/24/18 17:00	510,504	147	24.7	0.1
1/23/18 19:00	1/24/18 18:00	475,960	133	22.8	0.1
1/23/18 20:00	1/24/18 19:00	454,704	120	21.7	0.1
1/23/18 21:00	1/24/18 20:00	435,251	65	17.5	0.1
1/23/18 22:00	1/24/18 21:00	354,612	31	6.6	0.0
1/23/18 23:00	1/24/18 22:00	354,601	28	6.6	0.0
1/24/18 0:00	1/24/18 23:00	354,421	28	6.6	0.0
1/24/18 1:00	1/25/18 0:00	354,421	28	6.6	0.0
1/24/18 2:00	1/25/18 1:00	354,421	28	6.6	0.0
1/24/18 3:00	1/25/18 2:00	354,421	28	6.6	0.0
1/24/18 4:00	1/25/18 3:00	356,298	32	6.7	0.0
1/24/18 5:00	1/25/18 4:00	348,838	32	6.7	0.0
1/24/18 6:00	1/25/18 5:00	348,296	32	6.7	0.0
1/24/18 7:00	1/25/18 6:00	348,296	32	6.7	0.0
1/24/18 8:00	1/25/18 7:00	348,296	32	6.7	0.0
1/24/18 9:00	1/25/18 8:00	348,296	32	6.7	0.0
1/24/18 10:00	1/25/18 9:00	348,296	32	6.7	0.0
1/24/18 11:00	1/25/18 10:00	348,264	32	6.7	0.0
1/24/18 12:00	1/25/18 11:00	293,595	22	4.6	0.0
1/24/18 13:00	1/25/18 12:00	202,561	18	2.8	0.0
1/24/18 14:00	1/25/18 13:00	97,250	13	1.1	0.0
1/24/18 15:00	1/25/18 14:00	120,680	20	3.6	0.0
1/24/18 16:00	1/25/18 15:00	225,482	22	5.6	0.0
1/24/18 17:00	1/25/18 16:00	301,571	21	6.1	0.0
1/24/18 18:00	1/25/18 17:00	384,182	23	6.8	0.0
1/24/18 19:00	1/25/18 18:00	384,182	23	6.8	0.0
1/24/18 20:00	1/25/18 19:00	384,141	23	6.8	0.0
1/24/18 21:00	1/25/18 20:00	384,141	23	6.8	0.0
1/24/18 22:00	1/25/18 21:00	386,460	25	6.9	0.0
1/24/18 23:00	1/25/18 22:00	386,460	25	6.9	0.0
1/25/18 0:00	1/25/18 23:00	386,460	25	6.9	0.0
1/25/18 1:00	1/26/18 0:00	386,460	25	6.9	0.0
1/25/18 2:00	1/26/18 1:00	386,460	25	6.9	0.0
1/25/18 3:00	1/26/18 2:00	386,460	25	6.9	0.0
1/25/18 4:00	1/26/18 3:00	384,582	20	6.8	0.0
1/25/18 5:00	1/26/18 4:00	384,582	20	6.8	0.0
1/25/18 6:00	1/26/18 5:00	384,582	20	6.8	0.0
1/25/18 7:00	1/26/18 6:00	392,350	20	6.8	0.0
1/25/18 8:00	1/26/18 7:00	449,694	33	9.7	0.1
1/25/18 9:00	1/26/18 8:00	454,367	53	10.1	0.1
1/25/18 10:00	1/26/18 9:00	454,399	58	10.1	0.1

(8.)

The measured or calculated cumulative quantity of gas discharged over the discharge duration.

Note: Measured sulfur concentrations are shown as flow-weighted averages if multiple measurement devices were used.

		(60.108a(c)(6)(iii))	(60.108a(c)(6)(iv))	(60.108a(c)(6)(vii))	(60.108a(c)(6)(vii))
First hour of 24-hr Period	Last hour of 24-hr Period	24-hr cumulative volume of flared gas above Baseline	TRS or H2S ppm (24-hr average, flow-weighted)	24-hr cumulative SO2	24-hr cumulative reduced sulfur
		SCF	ppmv	lbs	lbs as H2S
1/25/18 11:00	1/26/18 10:00	470,971	137	15.2	0.1
1/25/18 12:00	1/26/18 11:00	499,157	183	20.3	0.1
1/25/18 13:00	1/26/18 12:00	517,915	274	27.1	0.1
1/25/18 14:00	1/26/18 13:00	543,913	302	30.0	0.2
1/25/18 15:00	1/26/18 14:00	487,115	416	40.1	0.2

Subpart Ja Root Cause / Corrective Action AnalysisIncident Number: 350609/350639*The information contained below satisfies the requirements of the NSPS Subpart Ja 60.108a(c)(6).*

Report: Initial
 Refinery: Valero (Meraux)
 Incident Type: Flaring (Flow)
 Emissions Source(s): North Flare (EPN 20-72, EQT 0035)

Date of Event: 1/28/18
 Date Analysis Completed: 3/8/18

(1.) (60.108a(c)(6)(i))

A description of the Discharge:

On January 28, 2018 at 12:53. Valero began flaring clean Hydrogen from the Reformer as part of a normal unit start up. The refinery was restarting units after the power failure and complete refinery shutdown on 1/16/18. The Reformer is a Hydrogen producing unit, but it does not produce Hydrogen at a high enough pressure to be used by most units in the refinery. This requires the Reformers' Net Gas Compressor to be running. The Net Gas Compressor sends this Hydrogen to the Pressure Swing Absorption (PSA) Unit. The PSA also has a Tail Gas Compressor to compress the offgas from the Hydrogen purification process and send it to fuel gas. Excess Hydrogen is also sent to the fuel gas system with this tail gas. Consequentially, the Tail Gas Compressor must running before the Net Gas Compressor is started or else the Hydrogen being flared just ends up back in the flare.

Valero was unable to start a PSA Tail Gas Compressor when it was required to minimize the volume of Hydrogen flared.

(2.) (60.108a(c)(6)(ii) and (60.108a(c)(6)(ix))

	North Flare
Date and Time the discharge was first identified	<u>1/28/18 12:53</u>
Date/Time the discharge had ceased	<u>1/29/18 2:27</u>
Duration of Discharge (Calculated)	<u>13.6</u>

(3.) (60.108a(c)(6)(viii))

The steps taken to limit the emissions during the discharge:

Valero halted the start up of the Reformer Unit and minimized the amount of Hydrogen produced and began troubleshooting the PSA Tail Gas Compressors.

(4.) (60.108a(c)(6)(xi))

Necessity of RC/CAA: Determine and state whether a RC/CAA is necessary:

Note: If the discharge was a result of a planned startup or shutdown, a RC/CAA analysis is not required if the flare management plan was followed.

Did the discharge result from a planned startup or shutdown? No (Yes/No)
 Was the flare management plan followed? Yes (Yes/No/N/A)
 Is the event exempt from a RC/CCA based on the answers above? No (Yes/No)
 - If yes, skip section 5-7.

(5.) (60.108a(c)(6)(ix))

Root Cause Analysis: Describe in detail the Root Cause(s) of the Incident, to the extent determinable:

Did this discharge result from root causes identified in a previous analysis? No (Yes/No)

Valero determined the root cause(s) of this incident to be not ensuring that the PSA Tail Gas Compressor was available prior to beginning the Reformer Unit start up. The Net Gas Compressor needs the PSA Tail Gas Compressor to stay out of the flare, but the PSA Tail Gas Compressor does not need the Net Gas Compressor to be running. Also, neither of the PSA Tail Gas Compressors could be started due to operation of the lube oil system for extended periods with non running compressors with their discharge valves open. The PSA Tail Gas Compressors are wetted-screw compressors where the lube oil and process gas are mixed in the suction of the machine. After compression, this oil gas mixture goes to an Oil Separator to drop out the oil, which is then reused. The Oil Separator is also the reservoir where excess oil is stored. If the lube oil system is operated for a long time without the discharge valve shut on a non running compressor the oil migrates from the Oil Separator back to the screw case and fills it with oil. The compressor will not start until enough of this oil is removed from the case, either by manual draining, or successive start attempts pumping it out.

(6.)

(60.108a(c)(6)(ix))

Corrective Action Analysis: Include a description of the recommended corrective action(s) or an explanation of why corrective action is not necessary.

Is corrective action required? Yes (Yes/No)

- 1) *Add a warning to the Reformer Startup Procedure(s) saying that a PSA Tail Gas Compressor should be running prior to beginning Reformer Start Up to minimize flaring, or plan for an alternative location for the Hydrogen.*
- 2) *Evaluate the possibility of installing a means of determining the oil level in the compressor case and, if feasible, add a step to the Tail Gas Compressor startup procedure to check this level.*
- 3) *Revise PSA Tail Gas Compressor Operating Procedures, as necessary, to minimize the potential for excessive oil migration into the case of a non-running machine and preventing the compressor from starting.*

(7.)

(60.108a(c)(6)(x))

Corrective Action Schedule: Include corrective actions already completed within the first 45 days following the discharge. For those not completed, provide a schedule for implementation, including proposed commencement and completion dates.

- 1) *Add a warning to the Reformer Startup Procedure(s) saying that a PSA Tail Gas Compressor should be running prior to beginning Reformer Start Up to minimize flaring, or plan for an alternative location for the Hydrogen.*

Commencement Date: 3/8/18

Estimated Completion Date: 6/5/18

- 2) *Evaluate the possibility of installing a means of determining the oil level in the compressor case and, if feasible, add a step to the Tail Gas Compressor startup procedure to check this level.*

Commencement Date: 3/8/18

Estimated Completion Date: 6/5/18

- 3) *Revise PSA Tail Gas Compressor Operating Procedures, as necessary, to minimize the potential for excessive oil migration into the case of a non-running machine and preventing the compressor from starting.*

Commencement Date: 3/8/18

Estimated Completion Date: 6/5/18

(8.) North and South Flares

The measured or calculated cumulative quantity of gas discharged over the discharge duration.

Note: Measured sulfur concentrations are shown as flow-weighted averages if multiple measurement devices were used.

		(60.108a(c)(6)(iii))	(60.108a(c)(6)(iv))	(60.108a(c)(6)(vii))	(60.108a(c)(6)(vii))
		24-hr cumulative volume of flared gas above Baseline	TRS or H2S ppm (24-hr average, flow- weighted)	24-hr cumulative SO2	24-hr cumulative reduced sulfur
First hour of 24-hr Period	Last hour of 24-hr Period	SCF	ppmv	lbs	lbs as H2S
1/27/18 12:00	1/28/18 11:00	173,399	235	19	0
1/27/18 13:00	1/28/18 12:00	175,262	250	19.1	0.1
1/27/18 14:00	1/28/18 13:00	335,045	261	26.4	0.1
1/27/18 15:00	1/28/18 14:00	748,772	265	31.8	0.2
1/27/18 16:00	1/28/18 15:00	1,139,097	267	35.6	0.2
1/27/18 17:00	1/28/18 16:00	1,535,650	270	39.2	0.2
1/27/18 18:00	1/28/18 17:00	1,757,480	273	42.5	0.2
1/27/18 19:00	1/28/18 18:00	1,885,523	279	45.4	0.2
1/27/18 20:00	1/28/18 19:00	1,996,272	286	48.3	0.3
1/27/18 21:00	1/28/18 20:00	2,102,207	292	51.0	0.3
1/27/18 22:00	1/28/18 21:00	2,190,206	299	53.3	0.3
1/27/18 23:00	1/28/18 22:00	2,206,080	309	55.4	0.3
1/28/18 0:00	1/28/18 23:00	2,183,993	306	53.7	0.3
1/28/18 1:00	1/29/18 0:00	2,215,627	226	51.8	0.3
1/28/18 2:00	1/29/18 1:00	2,242,031	235	52.8	0.3
1/28/18 3:00	1/29/18 2:00	2,246,873	245	52.9	0.3
1/28/18 4:00	1/29/18 3:00	2,247,148	247	52.9	0.3
1/28/18 5:00	1/29/18 4:00	2,247,148	247	52.9	0.3
1/28/18 6:00	1/29/18 5:00	2,247,148	247	52.9	0.3
1/28/18 7:00	1/29/18 6:00	2,247,148	247	52.9	0.3
1/28/18 8:00	1/29/18 7:00	2,247,358	248	52.9	0.3
1/28/18 9:00	1/29/18 8:00	2,247,358	248	52.9	0.3
1/28/18 10:00	1/29/18 9:00	2,235,595	176	49.1	0.3
1/28/18 11:00	1/29/18 10:00	2,211,140	120	41.0	0.2
1/28/18 12:00	1/29/18 11:00	2,215,819	126	41.1	0.2
1/28/18 13:00	1/29/18 12:00	2,215,784	114	41.0	0.2
1/28/18 14:00	1/29/18 13:00	2,062,181	107	33.8	0.2
1/28/18 15:00	1/29/18 14:00	1,669,453	119	29.6	0.2
1/28/18 16:00	1/29/18 15:00	1,279,437	122	25.9	0.1
1/28/18 17:00	1/29/18 16:00	882,884	119	22.2	0.1
1/28/18 18:00	1/29/18 17:00	661,054	116	18.9	0.1
1/28/18 19:00	1/29/18 18:00	533,011	110	16.0	0.1
1/28/18 20:00	1/29/18 19:00	422,262	103	13.2	0.1

Subpart Ja Root Cause / Corrective Action AnalysisIncident Number: 350695*The information contained below satisfies the requirements of the NSPS Subpart Ja 60.108a(c)(6).*
 Report: Final
 Refinery: Valero (Meraux)
 Incident Type: Flaring (Flow)
 Emissions Source(s): North Flare (EPN 20-72, EQT 0035)

 Date of Event: 1/31/18
 Date Analysis Completed: 3/1/18
(1.) (60.108a(c)(6)(i))**A description of the Discharge:**

On January 31, 2018 at 11:18, the running Hydrocracker Unit (HCU) Charge Pump was inadvertently shut down due to physical contact with the local start/stop switch at the pump. The HCU automatically shutdown due to low flow conditions, but an emergency depressurization was not required. Flaring was primarily excess Hydrogen with a very low H2S concentration.

(2.) (60.108a(c)(6)(ii) and (60.108a(c)(6)(ix)))

	North Flare
Date and Time the discharge was first identified	<u>1/31/18 11:32</u>
Date/Time the discharge had ceased	<u>1/31/18 18:30</u>
Duration of Discharge (Calculated)	<u>7.0</u>

(3.) (60.108a(c)(6)(viii))**The steps taken to limit the emissions during the discharge:**

Valero initiated its refinery sulfur shedding procedure and followed its Flare Minimization Plan and Operations Procedures to minimize the volume and SO2 emissions of this discharge.

(4.) (60.108a(c)(6)(xi))**Necessity of RC/CAA: Determine and state whether a RC/CAA is necessary:**

Note: If the discharge was a result of a planned startup or shutdown, a RC/CAA analysis is not required if the flare management plan was followed.

Did the discharge result from a planned startup or shutdown?	<u>No</u>	(Yes/No)
Was the flare management plan followed?	<u>Yes</u>	(Yes/No/N/A)
Is the event exempt from a RC/CCA based on the answers above?	<u>No</u>	(Yes/No)

- If yes, skip section 5-7.

(5.) (60.108a(c)(6)(ix))**Root Cause Analysis: Describe in detail the Root Cause(s) of the Incident, to the extent determinable:**

Did this discharge result from root causes identified in a previous analysis? No (Yes/No)

The root cause of this incident was contact with the local start/stop switch by a scaffolding crew that was dismantling a scaffold above the other, non-running, HCU Charge Pump. The protective switch cover was also missing from the switch.

(6.) (60.108a(c)(6)(ix))**Corrective Action Analysis: Include a description of the recommended corrective action(s) or an explanation of why corrective action is not necessary.**

Is corrective action required? Yes (Yes/No)

1) Install a new protective cover.

3) Implement a sensitive equipment checklist to be reviewed in pre-job walkdowns and review it with the scaffolding contractor.

(7.) (60.108a(c)(6)(x))**Corrective Action Schedule: Include corrective actions already completed within the first 45 days following the discharge. For those not completed, provide a schedule for implementation, including proposed commencement and completion dates.**

1) Install a new protective cover.

Completed

2) Implement a sensitive equipment checklist to be reviewed in pre-job walkdowns and review it with the scaffolding contractor.

Commencement Date: 3/11/18

Completed Date: 4/2/18

(8.) North and South Flares

The measured or calculated cumulative quantity of gas discharged over the discharge duration.

Note: Measured sulfur concentrations are shown as flow-weighted averages if multiple measurement devices were used.

		(60.108a(c)(6)(iii))	(60.108a(c)(6)(iv))	(60.108a(c)(6)(vii))	(60.108a(c)(6)(vii))
First hour of 24-hr Period	Last hour of 24-hr Period	24-hr cumulative volume of flared gas above Baseline	TRS or H2S ppm (24-hr average, flow-weighted)	24-hr cumulative SO2	24-hr cumulative reduced sulfur
		SCF	ppmv	lbs	lbs as H2S
1/30/18 11:00	1/31/18 10:00	13,811	352	14	0
1/30/18 12:00	1/31/18 11:00	114,920	354	16.0	0.1
1/30/18 13:00	1/31/18 12:00	325,101	355	19.1	0.1
1/30/18 14:00	1/31/18 13:00	537,021	358	21.5	0.1
1/30/18 15:00	1/31/18 14:00	902,413	12	8.0	0.0
1/30/18 16:00	1/31/18 15:00	1,258,663	12	8.4	0.0
1/30/18 17:00	1/31/18 16:00	1,513,831	13	9.5	0.1
1/30/18 18:00	1/31/18 17:00	1,757,729	25	21.0	0.1
1/30/18 19:00	1/31/18 18:00	1,803,080	51	25.6	0.1
1/30/18 20:00	1/31/18 19:00	1,803,080	51	25.6	0.1
1/30/18 21:00	1/31/18 20:00	1,803,080	51	25.6	0.1
1/30/18 22:00	1/31/18 21:00	1,803,080	51	25.6	0.1
1/30/18 23:00	1/31/18 22:00	1,803,080	51	25.6	0.1
1/31/18 0:00	1/31/18 23:00	1,803,080	51	25.6	0.1
1/31/18 1:00	2/1/18 0:00	1,803,080	51	25.6	0.1
1/31/18 2:00	2/1/18 1:00	1,803,080	51	25.6	0.1
1/31/18 3:00	2/1/18 2:00	1,803,080	51	25.6	0.1
1/31/18 4:00	2/1/18 3:00	1,803,080	51	25.6	0.1
1/31/18 5:00	2/1/18 4:00	1,803,080	51	25.6	0.1
1/31/18 6:00	2/1/18 5:00	1,803,080	51	25.6	0.1
1/31/18 7:00	2/1/18 6:00	1,803,080	51	25.6	0.1
1/31/18 8:00	2/1/18 7:00	1,805,236	55	25.7	0.1
1/31/18 9:00	2/1/18 8:00	1,805,236	55	25.7	0.1
1/31/18 10:00	2/1/18 9:00	1,805,236	55	25.7	0.1
1/31/18 11:00	2/1/18 10:00	1,805,236	55	25.7	0.1
1/31/18 12:00	2/1/18 11:00	1,702,609	51	23.8	0.1
1/31/18 13:00	2/1/18 12:00	1,490,403	47	20.6	0.1
1/31/18 14:00	2/1/18 13:00	1,278,483	44	18.2	0.1
1/31/18 15:00	2/1/18 14:00	902,823	44	17.7	0.1
1/31/18 16:00	2/1/18 15:00	546,573	43	17.2	0.1
1/31/18 17:00	2/1/18 16:00	291,406	42	16.2	0.1
1/31/18 18:00	2/1/18 17:00	47,507	30	4.7	0.0

Subpart Ja Root Cause / Corrective Action AnalysisIncident Number: N/A*The information contained below satisfies the requirements of the NSPS Subpart Ja 60.108a(c)(6).*

Report: Final
 Refinery: Valero (Meraux)
 Incident Type: Flaring (Flow)
 Emissions Source(s): North Flare (EPN 20-72, EQT 0035)

Date of Event: 2/10/18
 Date Analysis Completed: N/A

(1.) (60.108a(c)(6)(i))**A description of the Discharge:**

Flaring during a Reformer Unit shutdown following a small fire on the Crude Unit. The fire damaged some level instrumentation and Valero made the decision to shutdown the Crude Unit for repairs. This required the Reformer Unit and other downstream units to be shut down as well.

(2.) (60.108a(c)(6)(ii) and (60.108a(c)(6)(ix))

Date and Time the discharge was first identified 2/10/18 21:46
 Date/Time the discharge had ceased 2/11/18 2:48
 Duration of Discharge (Calculated) 5.0 hrs

(3.) (60.108a(c)(6)(viii))**The steps taken to limit the emissions during the discharge:**

Valero followed its Flare Minimization Plan and Operations Procedures to minimize the volume of this discharge.

(4.) (60.108a(c)(6)(xi))**Necessity of RC/CAA: Determine and state whether a RC/CAA is necessary:**

Note: If the discharge was a result of a planned startup or shutdown, a RC/CAA analysis is not required if the flare management plan was followed.

Did the discharge result from a planned startup or shutdown? Yes (Yes/No)
 Was the flare management plan followed? Yes (Yes/No/N/A)
 Is the event exempt from a RC/CCA based on the answers above? Yes (Yes/No)
 - If yes, skip section 5-7.

(5.) (60.108a(c)(6)(ix))**Root Cause Analysis: Describe in detail the Root Cause(s) of the Incident, to the extent determinable:**

Did this discharge result from root causes identified in a previous analysis? No (Yes/No)
 N/A

(6.) (60.108a(c)(6)(ix))**Corrective Action Analysis: Include a description of the recommended corrective action(s) or an explanation of why corrective action is not necessary.**

Is corrective action required? No (Yes/No)
 N/A

(7.) (60.108a(c)(6)(x))**Corrective Action Schedule: Include corrective actions already completed within the first 45 days following the discharge. For those not completed, provide a schedule for implementation, including proposed commencement and completion dates.**

N/A

(8.)

The measured or calculated cumulative quantity of gas discharged over the discharge duration.

Note: Measured sulfur concentrations are shown as flow-weighted averages if multiple measurement devices were used.

		(60.108a(c)(6)(iii))	(60.108a(c)(6)(iv))	(60.108a(c)(6)(vii))	(60.108a(c)(6)(vii))
First hour of 24-hr Period	Last hour of 24-hr Period	24-hr cumulative volume of flared gas above Baseline	TRS or H2S ppm (24-hr average, flow- weighted)	24-hr cumulative SO2	24-hr cumulative reduced sulfur
		SCF	ppmv	lbs	lbs as H2S
2/9/18 21:00	2/10/18 20:00	0	0	0.0	0.0
2/9/18 22:00	2/10/18 21:00	29,184	1	0.1	0.0
2/9/18 23:00	2/10/18 22:00	100,690	6	1.6	0.0
2/10/18 0:00	2/10/18 23:00	307,059	12	6.0	0.0
2/10/18 1:00	2/11/18 0:00	468,805	16	8.6	0.0
2/10/18 2:00	2/11/18 1:00	642,226	18	9.8	0.1
2/10/18 3:00	2/11/18 2:00	736,618	19	10.4	0.1
2/10/18 4:00	2/11/18 3:00	779,173	19	10.4	0.1
2/10/18 5:00	2/11/18 4:00	795,208	19	10.4	0.1
2/10/18 6:00	2/11/18 5:00	800,664	19	10.4	0.1
2/10/18 7:00	2/11/18 6:00	829,984	19	10.4	0.1
2/10/18 8:00	2/11/18 7:00	844,849	19	10.4	0.1
2/10/18 9:00	2/11/18 8:00	844,849	19	10.4	0.1
2/10/18 10:00	2/11/18 9:00	844,849	19	10.4	0.1
2/10/18 11:00	2/11/18 10:00	844,849	19	10.4	0.1
2/10/18 12:00	2/11/18 11:00	844,849	19	10.4	0.1
2/10/18 13:00	2/11/18 12:00	844,849	19	10.4	0.1
2/10/18 14:00	2/11/18 13:00	844,849	19	10.4	0.1
2/10/18 15:00	2/11/18 14:00	844,945	19	10.4	0.1
2/10/18 16:00	2/11/18 15:00	845,273	19	10.4	0.1
2/10/18 17:00	2/11/18 16:00	845,273	19	10.4	0.1
2/10/18 18:00	2/11/18 17:00	845,273	19	10.4	0.1
2/10/18 19:00	2/11/18 18:00	845,273	19	10.4	0.1
2/10/18 20:00	2/11/18 19:00	845,273	19	10.4	0.1
2/10/18 21:00	2/11/18 20:00	845,273	19	10.4	0.1
2/10/18 22:00	2/11/18 21:00	816,089	18	10.3	0.1
2/10/18 23:00	2/11/18 22:00	744,583	13	8.8	0.0
2/11/18 0:00	2/11/18 23:00	538,396	8	4.4	0.0
2/11/18 1:00	2/12/18 0:00	379,518	4	1.8	0.0

Subpart Ja Root Cause / Corrective Action AnalysisIncident Number: N/A*The information contained below satisfies the requirements of the NSPS Subpart Ja 60.108a(c)(6).*

Report: Final
 Refinery: Valero (Meraux)
 Incident Type: Flaring (Flow)
 Emissions Source(s): North Flare (EPN 20-72, EQT 0035)

Date of Event: 2/15/18
 Date Analysis Completed: N/A

(1.) (60.108a(c)(6)(i))

A description of the Discharge:
Flaring during Reformer Unit start up.

(2.) (60.108a(c)(6)(ii) and (60.108a(c)(6)(ix))

Date and Time the discharge was first identified 2/15/18 6:57
 Date/Time the discharge had ceased 2/15/18 8:58
 Duration of Discharge (Calculated) 2.0 hrs

(3.) (60.108a(c)(6)(viii))

The steps taken to limit the emissions during the discharge:
Valero followed its Flare Minimization Plan and Operations Procedures to minimize the volume of this discharge.

(4.) (60.108a(c)(6)(xi))

Necessity of RC/CAA: Determine and state whether a RC/CAA is necessary:
Note: If the discharge was a result of a planned startup or shutdown, a RC/CAA analysis is not required if the flare management plan was followed.

Did the discharge result from a planned startup or shutdown? Yes (Yes/No)
 Was the flare management plan followed? Yes (Yes/No/N/A)
 Is the event exempt from a RC/CCA based on the answers above? Yes (Yes/No)
 - If yes, skip section 5-7.

(5.) (60.108a(c)(6)(ix))

Root Cause Analysis: Describe in detail the Root Cause(s) of the Incident, to the extent determinable:
 Did this discharge result from root causes identified in a previous analysis? No (Yes/No)
 N/A

(6.) (60.108a(c)(6)(ix))

Corrective Action Analysis: Include a description of the recommended corrective action(s) or an explanation of why corrective action is not necessary.
 Is corrective action required? No (Yes/No)
 N/A

(7.) (60.108a(c)(6)(x))

Corrective Action Schedule: Include corrective actions already completed within the first 45 days following the discharge. For those not completed, provide a schedule for implementation, including proposed commencement and completion dates.
 N/A

(8.)

The measured or calculated cumulative quantity of gas discharged over the discharge duration.

Note: Measured sulfur concentrations are shown as flow-weighted averages if multiple measurement devices were used.

		(60.108a(c)(6)(iii))	(60.108a(c)(6)(iv))	(60.108a(c)(6)(vii))	(60.108a(c)(6)(vii))
First hour of 24-hr Period	Last hour of 24-hr Period	24-hr cumulative volume of flared gas above Baseline	TRS or H2S ppm (24-hr average, flow- weighted)	24-hr cumulative SO2	24-hr cumulative reduced sulfur
		SCF	ppmv	lbs	lbs as H2S
2/14/18 6:00	2/15/18 5:00	66,159	75	5.8	0.0
2/14/18 7:00	2/15/18 6:00	78,282	78	5.9	0.0
2/14/18 8:00	2/15/18 7:00	259,274	83	9.6	0.1
2/14/18 9:00	2/15/18 8:00	693,352	83	9.8	0.1
2/14/18 10:00	2/15/18 9:00	693,352	83	9.8	0.1
2/14/18 11:00	2/15/18 10:00	689,821	82	9.8	0.1
2/14/18 12:00	2/15/18 11:00	695,337	86	9.8	0.1
2/14/18 13:00	2/15/18 12:00	695,337	86	9.8	0.1
2/14/18 14:00	2/15/18 13:00	697,735	174	10.7	0.1
2/14/18 15:00	2/15/18 14:00	697,735	174	10.7	0.1
2/14/18 16:00	2/15/18 15:00	681,225	173	10.6	0.1
2/14/18 17:00	2/15/18 16:00	666,695	171	10.5	0.1
2/14/18 18:00	2/15/18 17:00	665,835	170	10.5	0.1
2/14/18 19:00	2/15/18 18:00	665,835	170	10.5	0.1
2/14/18 20:00	2/15/18 19:00	665,835	170	10.5	0.1
2/14/18 21:00	2/15/18 20:00	665,835	170	10.5	0.1
2/14/18 22:00	2/15/18 21:00	665,835	170	10.5	0.1
2/14/18 23:00	2/15/18 22:00	665,835	170	10.5	0.1
2/15/18 0:00	2/15/18 23:00	661,509	150	10.1	0.1
2/15/18 1:00	2/16/18 0:00	661,509	150	10.1	0.1
2/15/18 2:00	2/16/18 1:00	661,509	150	10.1	0.1
2/15/18 3:00	2/16/18 2:00	661,509	150	10.1	0.1
2/15/18 4:00	2/16/18 3:00	661,509	150	10.1	0.1
2/15/18 5:00	2/16/18 4:00	635,131	99	4.9	0.0
2/15/18 6:00	2/16/18 5:00	635,106	99	4.9	0.0
2/15/18 7:00	2/16/18 6:00	622,983	97	4.8	0.0
2/15/18 8:00	2/16/18 7:00	441,991	92	1.1	0.0
2/15/18 9:00	2/16/18 8:00	7,913	92	0.9	0.0

Subpart Ja Root Cause / Corrective Action AnalysisImpact Incident Number: N/A*The information contained below satisfies the requirements of the NSPS Subpart Ja 60.108a(c)(6).*

Report: Final
 Refinery: Valero (Meraux)
 Incident Type: Flaring (Flow)
 Emissions Source(s): North Flare (EPN 20-72, EQT 0035)

Date of Event: 2/16/18
 Date Analysis Completed: N/A

(1.) (60.108a(c)(6)(i))

A description of the Discharge:
Flaring during Kerosene Hydrotreater Unit shutdown for turnaround.

(2.) (60.108a(c)(6)(ii) and (60.108a(c)(6)(ix))

Date and Time the discharge was first identified 2/16/18 19:07
 Date/Time the discharge had ceased 2/17/18 16:12
 Duration of Discharge (Calculated) 21.1 hrs

(3.) (60.108a(c)(6)(viii))

The steps taken to limit the emissions during the discharge:
Valero followed its Flare Minimization Plan and Operations Procedures to minimize the volume of this discharge.

(4.) (60.108a(c)(6)(xi))

Necessity of RC/CAA: Determine and state whether a RC/CAA is necessary:
Note: If the discharge was a result of a planned startup or shutdown, a RC/CAA analysis is not required if the flare management plan was followed.

Did the discharge result from a planned startup or shutdown? Yes (Yes/No)
 Was the flare management plan followed? Yes (Yes/No/N/A)
 Is the event exempt from a RC/CCA based on the answers above? Yes (Yes/No)
 - If yes, skip section 5-7.

(5.) (60.108a(c)(6)(ix))

Root Cause Analysis: Describe in detail the Root Cause(s) of the Incident, to the extent determinable:
 Did this discharge result from root causes identified in a previous analysis? No (Yes/No)
 N/A

(6.) (60.108a(c)(6)(ix))

Corrective Action Analysis: Include a description of the recommended corrective action(s) or an explanation of why corrective action is not necessary.
 Is corrective action required? No (Yes/No)
 N/A

(7.) (60.108a(c)(6)(x))

Corrective Action Schedule: Include corrective actions already completed within the first 45 days following the discharge. For those not completed, provide a schedule for implementation, including proposed commencement and completion dates.
 N/A

(8.)

The measured or calculated cumulative quantity of gas discharged over the discharge duration.

Note: Measured sulfur concentrations are shown as flow-weighted averages if multiple measurement devices were used.

		(60.108a(c)(6)(iii))	(60.108a(c)(6)(iv))	(60.108a(c)(6)(vii))	(60.108a(c)(6)(vii))
First hour of 24-hr Period	Last hour of 24-hr Period	24-hr cumulative volume of flared gas above Baseline	TRS or H2S ppm (24-hr average, flow- weighted)	24-hr cumulative SO2	24-hr cumulative reduced sulfur
		SCF	ppmv	lbs	lbs as H2S
2/15/18 19:00	2/16/18 18:00	66,933	13	0.1	0.0
2/15/18 20:00	2/16/18 19:00	66,694	13	0.1	0.0
2/15/18 21:00	2/16/18 20:00	72,690	417	14.2	0.1
2/15/18 22:00	2/16/18 21:00	157,167	513	47.3	0.3
2/15/18 23:00	2/16/18 22:00	250,166	536	56.4	0.3
2/16/18 0:00	2/16/18 23:00	344,794	560	65.7	0.4
2/16/18 1:00	2/17/18 0:00	439,624	581	74.2	0.4
2/16/18 2:00	2/17/18 1:00	533,633	598	80.9	0.4
2/16/18 3:00	2/17/18 2:00	624,333	616	87.7	0.5
2/16/18 4:00	2/17/18 3:00	718,776	638	96.3	0.5
2/16/18 5:00	2/17/18 4:00	812,697	665	106.9	0.6
2/16/18 6:00	2/17/18 5:00	905,119	677	111.6	0.6
2/16/18 7:00	2/17/18 6:00	996,539	696	119.0	0.6
2/16/18 8:00	2/17/18 7:00	1,085,036	725	129.7	0.7
2/16/18 9:00	2/17/18 8:00	1,171,221	751	138.8	0.7
2/16/18 10:00	2/17/18 9:00	1,191,605	791	142.5	0.8
2/16/18 11:00	2/17/18 10:00	1,200,328	885	146.8	0.8
2/16/18 12:00	2/17/18 11:00	1,201,194	930	147.4	0.8
2/16/18 13:00	2/17/18 12:00	1,201,194	933	147.5	0.8
2/16/18 14:00	2/17/18 13:00	1,201,194	935	147.5	0.8
2/16/18 15:00	2/17/18 14:00	1,205,605	1123	152.9	0.8
2/16/18 16:00	2/17/18 15:00	1,224,146	1414	177.5	1.0
2/16/18 17:00	2/17/18 16:00	1,224,611	1451	177.9	1.0
2/16/18 18:00	2/17/18 17:00	1,224,611	1455	178.0	1.0
2/16/18 19:00	2/17/18 18:00	1,224,611	1460	178.0	1.0
2/16/18 20:00	2/17/18 19:00	1,224,851	1464	178.1	1.0
2/16/18 21:00	2/17/18 20:00	1,218,854	1063	164.1	0.9
2/16/18 22:00	2/17/18 21:00	1,134,377	971	131.0	0.7
2/16/18 23:00	2/17/18 22:00	1,041,378	950	121.9	0.7
2/17/18 0:00	2/17/18 23:00	946,750	929	112.6	0.6
2/17/18 1:00	2/18/18 0:00	851,920	910	104.2	0.6
2/17/18 2:00	2/18/18 1:00	757,912	895	97.5	0.5
2/17/18 3:00	2/18/18 2:00	667,211	879	90.7	0.5
2/17/18 4:00	2/18/18 3:00	572,768	859	82.2	0.4
2/17/18 5:00	2/18/18 4:00	478,847	833	71.5	0.4
2/17/18 6:00	2/18/18 5:00	386,425	823	66.9	0.4

Subpart Ja Root Cause / Corrective Action AnalysisIncident Number: N/A*The information contained below satisfies the requirements of the NSPS Subpart Ja 60.108a(c)(6).*

Report: Final
 Refinery: Valero (Meraux)
 Incident Type: Flaring (Flow)
 Emissions Source(s): North Flare (EPN 20-72, EQT 0035)

Date of Event: 3/17/18
 Date Analysis Completed: N/A

(1.) (60.108a(c)(6)(i))**A description of the Discharge:***Flaring during Naphtha Hydrotreater Unit shutdown for turnaround.***(2.)** (60.108a(c)(6)(ii) and (60.108a(c)(6)(ix))

Date and Time the discharge was first identified 3/17/18 22:20
 Date/Time the discharge had ceased 3/19/18 4:05
 Duration of Discharge (Calculated) 29.8 hrs

(3.) (60.108a(c)(6)(viii))**The steps taken to limit the emissions during the discharge:***Valero followed its Flare Minimization Plan and Operations Procedures to minimize the volume of this discharge.***(4.)** (60.108a(c)(6)(xi))**Necessity of RC/CAA: Determine and state whether a RC/CAA is necessary:***Note: If the discharge was a result of a planned startup or shutdown, a RC/CAA analysis is not required if the flare management plan was followed.*

Did the discharge result from a planned startup or shutdown? Yes (Yes/No)
 Was the flare management plan followed? Yes (Yes/No/N/A)
 Is the event exempt from a RC/CCA based on the answers above? Yes (Yes/No)
 - If yes, skip section 5-7.

(5.) (60.108a(c)(6)(ix))**Root Cause Analysis: Describe in detail the Root Cause(s) of the Incident, to the extent determinable:**Did this discharge result from root causes identified in a previous analysis? No (Yes/No)*N/A***(6.)** (60.108a(c)(6)(ix))**Corrective Action Analysis: Include a description of the recommended corrective action(s) or an explanation of why corrective action is not**Is corrective action required? No (Yes/No)*N/A***(7.)** (60.108a(c)(6)(x))**Corrective Action Schedule: Include corrective actions already completed within the first 45 days following the discharge. For those not completed, provide a schedule for implementation, including proposed commencement and completion dates.***N/A*

(8.)					
The measured or calculated cumulative quantity of gas discharged over the discharge duration.					
<i>Note: Measured sulfur concentrations are shown as flow-weighted averages if multiple measurement devices were used.</i>					
		(60.108a(c)(6)(iii))	(60.108a(c)(6)(iv))	(60.108a(c)(6)(vii))	(60.108a(c)(6)(vii))
First hour of 24-hr Period	Last hour of 24-hr Period	24-hr cumulative volume of flared gas above Baseline	TRS or H2S ppm (24-hr average, flow-weighted)	24-hr cumulative SO2	24-hr cumulative reduced sulfur
		SCF	ppmv	lbs	lbs as H2S
3/16/18 22:00	3/17/18 21:00	97,480	23	2.3	0.0
3/16/18 23:00	3/17/18 22:00	104,918	26	2.4	0.0
3/17/18 0:00	3/17/18 23:00	120,108	78	6.1	0.0
3/17/18 1:00	3/18/18 0:00	128,191	171	10.1	0.1
3/17/18 2:00	3/18/18 1:00	129,760	175	10.2	0.1
3/17/18 3:00	3/18/18 2:00	142,829	199	11.7	0.1
3/17/18 4:00	3/18/18 3:00	156,198	205	12.1	0.1
3/17/18 5:00	3/18/18 4:00	169,333	205	12.1	0.1
3/17/18 6:00	3/18/18 5:00	183,989	212	12.6	0.1
3/17/18 7:00	3/18/18 6:00	192,833	221	13.0	0.1
3/17/18 8:00	3/18/18 7:00	213,750	221	13.0	0.1
3/17/18 9:00	3/18/18 8:00	238,503	222	13.2	0.1
3/17/18 10:00	3/18/18 9:00	258,437	226	13.6	0.1
3/17/18 11:00	3/18/18 10:00	281,905	227	13.7	0.1
3/17/18 12:00	3/18/18 11:00	323,024	229	14.1	0.1
3/17/18 13:00	3/18/18 12:00	404,345	230	14.2	0.1
3/17/18 14:00	3/18/18 13:00	508,149	229	14.3	0.1
3/17/18 15:00	3/18/18 14:00	629,213	229	14.3	0.1
3/17/18 16:00	3/18/18 15:00	729,949	229	14.4	0.1
3/17/18 17:00	3/18/18 16:00	815,866	229	14.5	0.1
3/17/18 18:00	3/18/18 17:00	904,913	230	14.7	0.1
3/17/18 19:00	3/18/18 18:00	1,014,427	230	14.9	0.1
3/17/18 20:00	3/18/18 19:00	1,120,372	213	12.7	0.1
3/17/18 21:00	3/18/18 20:00	1,262,234	212	12.7	0.1
3/17/18 22:00	3/18/18 21:00	1,409,939	211	12.7	0.1
3/17/18 23:00	3/18/18 22:00	1,498,983	208	12.7	0.1
3/18/18 0:00	3/18/18 23:00	1,603,725	156	9.0	0.0
3/18/18 1:00	3/19/18 0:00	1,719,841	63	5.1	0.0
3/18/18 2:00	3/19/18 1:00	1,838,544	59	5.2	0.0
3/18/18 3:00	3/19/18 2:00	1,970,984	35	4.2	0.0
3/18/18 4:00	3/19/18 3:00	2,029,711	31	4.2	0.0
3/18/18 5:00	3/19/18 4:00	2,016,576	35	4.2	0.0
3/18/18 6:00	3/19/18 5:00	2,001,920	31	3.7	0.0
3/18/18 7:00	3/19/18 6:00	1,993,076	26	3.4	0.0
3/18/18 8:00	3/19/18 7:00	1,972,159	28	3.4	0.0
3/18/18 9:00	3/19/18 8:00	1,947,406	28	3.2	0.0
3/18/18 10:00	3/19/18 9:00	1,927,471	25	2.8	0.0
3/18/18 11:00	3/19/18 10:00	1,904,003	26	2.8	0.0
3/18/18 12:00	3/19/18 11:00	1,862,884	25	2.4	0.0
3/18/18 13:00	3/19/18 12:00	1,781,564	26	2.3	0.0
3/18/18 14:00	3/19/18 13:00	1,677,760	27	2.2	0.0
3/18/18 15:00	3/19/18 14:00	1,556,695	28	2.2	0.0
3/18/18 16:00	3/19/18 15:00	1,455,959	29	2.1	0.0
3/18/18 17:00	3/19/18 16:00	1,370,042	30	2.0	0.0
3/18/18 18:00	3/19/18 17:00	1,280,995	31	1.8	0.0
3/18/18 19:00	3/19/18 18:00	1,171,482	32	1.7	0.0
3/18/18 20:00	3/19/18 19:00	1,034,989	33	1.7	0.0
3/18/18 21:00	3/19/18 20:00	893,127	34	1.6	0.0

(8.)

The measured or calculated cumulative quantity of gas discharged over the discharge duration.

Note: Measured sulfur concentrations are shown as flow-weighted averages if multiple measurement devices were used.

		(60.108a(c)(6)(iii))	(60.108a(c)(6)(iv))	(60.108a(c)(6)(vii))	(60.108a(c)(6)(vii))
First hour of 24-hr Period	Last hour of 24-hr Period	24-hr cumulative volume of flared gas above Baseline	TRS or H2S ppm (24-hr average, flow-weighted)	24-hr cumulative SO2	24-hr cumulative reduced sulfur
		SCF	ppmv	lbs	lbs as H2S
3/18/18 22:00	3/19/18 21:00	745,422	36	1.6	0.0
3/18/18 23:00	3/19/18 22:00	648,941	37	1.5	0.0
3/19/18 0:00	3/19/18 23:00	529,008	38	1.5	0.0
3/19/18 1:00	3/20/18 0:00	404,810	39	1.5	0.0

Subpart Ja Root Cause / Corrective Action Analysis

Impact Incident Number: **359746**

The information contained below satisfies the requirements of the NSPS Subpart Ja 60.108a(c)(6).

Report: Initial
 Refinery: Valero (Meraux)
 Incident Type: Flaring (Flow and SO2)
 Emissions Source(s): North Flare (EPN 20-72, EQT 0035)

Date of Event: 3/21/18
 Date Analysis Completed: 4/5/18

(1.) (60.108a(c)(6)(i))

A description of the Discharge:

On 3/21/18 at 09:06, while a maintenance technician was replacing 1 of 2 redundant field power supplies for the Hydrocracker (HCU) Safety Instrumented System (SIS) lost power and initiated a complete shutdown of the HCU including an emergency depressurization to the flare. Additional flaring continued until the HCU could be returned to normal operation due to Hydrogen system imbalance. Additional SO2 emissions also occurred at the #3 Sulfur Recovery Unit on the following day during start up.

(2.) (60.108a(c)(6)(ii)) and (60.108a(c)(6)(ix))

	North Flare	#3 SRU
Date and Time the discharge was first identified	<u>3/21/18 9:06</u>	<u>3/22/18 7:25</u>
Date/Time the discharge had ceased	<u>3/21/18 22:36</u>	<u>3/22/18 21:00</u>
Duration of Discharge (Calculated)	<u>13.5</u>	<u>13.6</u> hrs

(3.) (60.108a(c)(6)(viii))

The steps taken to limit the emissions during the discharge:

Valero initiated its refinery sulfur shedding procedure and followed its Flare Minimization Plan and Operations Procedures to minimize the volume and SO2 emissions of this discharge. Valero repaired the damaged chassis and replaced the redundant power supplies.

(4.) (60.108a(c)(6)(xi))

Necessity of RC/CAA: Determine and state whether a RC/CAA is necessary:

Note: If the discharge was a result of a planned startup or shutdown, a RC/CAA analysis is not required if the flare management plan was followed.

Did the discharge result from a planned startup or shutdown? No (Yes/No)
 Was the flare management plan followed? Yes (Yes/No/N/A)
 Is the event exempt from a RC/CCA based on the answers above? No (Yes/No)
 - If yes, skip section 5-7.

(5.) (60.108a(c)(6)(ix))

Root Cause Analysis: Describe in detail the Root Cause(s) of the Incident, to the extent determinable:

Did this discharge result from root causes identified in a previous analysis? No (Yes/No)

The root cause of this incident was a damaged 37 pin connector on the chassis where the power power supplies are connected to the system. The power supplies are completely redundant, but they do communicate with each other using this connection to coordinate the duration each one is provideing power to even out service life.

Valero has determined that this connection design (37 pin) is not robust enough for the way the power supplies are loaded into the chassis. The power supplies are heavy and the main AC and DC connections are tight fitting, so the power supply needs to be slid into the chassis with force. This force is enough to easily bend the pins or damage the connector if the chassis isn't perfectly aligned.

(6.) (60.108a(c)(6)(ix))

Corrective Action Analysis: Include a description of the recommended corrective action(s) or an explanation of why corrective action is not Is corrective action required? Yes (Yes/No)

1) *Conduct a survey of all Kepco power supplies in the plant and develop a plan to replace with Phoenix-type power supplies in upcoming outages.*

(7.)

(60.108a(c)(6)(x))

Corrective Action Schedule: Include corrective actions already completed within the first 45 days following the discharge. For those not completed, provide a schedule for implementation, including proposed commencement and completion dates.

1) Conduct a survey of all Kepco power supplies in the plant and develop a plan to replace with Phoenix-type power supplies in upcoming outages.

Commencement Date: 4/5/18

Estimated Completion Date: 6/5/18

(8.) North and South Flares

The measured or calculated cumulative quantity of gas discharged over the discharge duration.

Note: Measured sulfur concentrations are shown as flow-weighted averages if multiple measurement devices were used.

		(60.108a(c)(6)(iii))	(60.108a(c)(6)(iv))	(60.108a(c)(6)(vii))	(60.108a(c)(6)(vii))
First hour of 24-hr Period	Last hour of 24-hr Period	24-hr cumulative volume of flared gas above Baseline	TRS or H2S ppm (24-hr average, flow-weighted)	24-hr cumulative SO2	24-hr cumulative reduced sulfur
		SCF	ppmv	lbs	lbs as H2S
3/20/18 9:00	3/21/18 8:00	0	0	0	0
3/20/18 10:00	3/21/18 9:00	1,760,142	313	2176.7	11.7
3/20/18 11:00	3/21/18 10:00	3,086,350	463	2964.9	15.9
3/20/18 12:00	3/21/18 11:00	3,909,813	488	3044.1	16.4
3/20/18 13:00	3/21/18 12:00	5,320,567	586	3593.7	19.3
3/20/18 14:00	3/21/18 13:00	6,671,527	653	3952.9	21.2
3/20/18 15:00	3/21/18 14:00	7,965,280	732	4356.5	23.4
3/20/18 16:00	3/21/18 15:00	8,734,870	734	4360.7	23.4
3/20/18 17:00	3/21/18 16:00	9,496,971	735	4363.3	23.4
3/20/18 18:00	3/21/18 17:00	10,266,462	735	4365.1	23.5
3/20/18 19:00	3/21/18 18:00	11,185,479	737	4370.3	23.5
3/20/18 20:00	3/21/18 19:00	11,999,827	737	4373.3	23.5
3/20/18 21:00	3/21/18 20:00	12,799,897	739	4378.0	23.5
3/20/18 22:00	3/21/18 21:00	13,328,089	741	4381.8	23.5
3/20/18 23:00	3/21/18 22:00	13,410,146	745	4383.2	23.6
3/21/18 0:00	3/21/18 23:00	13,410,146	745	4383.2	23.6
3/21/18 1:00	3/22/18 0:00	13,410,146	745	4383.2	23.6
3/21/18 2:00	3/22/18 1:00	13,410,146	745	4383.2	23.6
3/21/18 3:00	3/22/18 2:00	13,410,146	745	4383.2	23.6
3/21/18 4:00	3/22/18 3:00	13,410,146	745	4383.2	23.6
3/21/18 5:00	3/22/18 4:00	13,410,146	745	4383.2	23.6
3/21/18 6:00	3/22/18 5:00	13,446,303	763	4385.7	23.6
3/21/18 7:00	3/22/18 6:00	13,675,917	773	4395.4	23.6
3/21/18 8:00	3/22/18 7:00	13,884,286	784	4404.2	23.7
3/21/18 9:00	3/22/18 8:00	13,884,286	784	4404.2	23.7
3/21/18 10:00	3/22/18 9:00	12,124,144	471	2227.5	12.0
3/21/18 11:00	3/22/18 10:00	10,797,936	321	1439.3	7.7
3/21/18 12:00	3/22/18 11:00	9,975,944	300	1360.1	7.3
3/21/18 13:00	3/22/18 12:00	8,565,190	202	810.5	4.4
3/21/18 14:00	3/22/18 13:00	7,214,230	135	451.3	2.4
3/21/18 15:00	3/22/18 14:00	5,921,761	71	47.7	0.3
3/21/18 16:00	3/22/18 15:00	5,152,171	69	43.6	0.2
3/21/18 17:00	3/22/18 16:00	4,390,070	69	41.0	0.2
3/21/18 18:00	3/22/18 17:00	3,620,579	68	39.2	0.2
3/21/18 19:00	3/22/18 18:00	2,701,562	67	34.0	0.2
3/21/18 20:00	3/22/18 19:00	1,887,229	67	31.0	0.2
3/21/18 21:00	3/22/18 20:00	1,087,158	66	26.3	0.1
3/21/18 22:00	3/22/18 21:00	560,196	75	22.6	0.1
3/21/18 23:00	3/22/18 22:00	478,139	71	21.2	0.1
3/22/18 0:00	1/0/00 0:00	478,139	71	21.2	0.1

(9.) #3 SRU

The measured or calculated cumulative quantity of gas discharged over the discharge duration.

Note: Measured sulfur concentrations are shown as flow-weighted averages if multiple measurement devices were used.

		(60.108a(c)(6)(iii))	(60.108a(c)(6)(vi))	(60.108a(c)(6)(vii))	(60.108a(c)(6)(vii))
First hour of 24-hr Period	Last hour of 24-hr Period	24-hr cumulative volume	SO ₂ ppm (24-hr average, flow-weighted) ¹	24-hr cumulative SO ₂ above allowable ²	24-hr cumulative reduced sulfur above allowable
		SCF	ppmv	lbs	lbs as H ₂ S
3/21/18 20:00	3/22/18 19:00	480,648	1000	479.0	2.6
3/21/18 21:00	3/22/18 20:00	469,086	880	527.5	2.8
3/21/18 22:00	3/22/18 21:00	391,374	105	527.5	2.8
3/21/18 23:00	3/22/18 22:00	371,836	65	527.5	2.8
3/22/18 0:00	3/22/18 23:00	342,994	66	527.5	2.8
3/22/18 1:00	3/23/18 0:00	357,600	60	527.5	2.8
3/22/18 2:00	3/23/18 1:00	350,381	56	527.5	2.8
3/22/18 3:00	3/23/18 2:00	364,928	53	527.5	2.8
3/22/18 4:00	3/23/18 3:00	374,980	48	527.5	2.8
3/22/18 5:00	3/23/18 4:00	400,348	46	527.5	2.8
3/22/18 6:00	3/23/18 5:00	431,683	48	527.5	2.8
3/22/18 7:00	3/23/18 6:00	436,076	46	527.5	2.8
3/22/18 8:00	3/23/18 7:00	449,882	30	518.4	2.8
3/22/18 9:00	3/23/18 8:00	466,155	21	475.4	2.6
3/22/18 10:00	3/23/18 9:00	515,287	25	475.4	2.6
3/22/18 11:00	3/23/18 10:00	522,525	25	472.2	2.5

¹ SRU SO₂ CEMS are spanned to 500 ppm. For emissions calculations, Valero assumes 2 times the span, 1000 ppm, for CEMS readings >= 500 ppm.

² Tail Gas Treater bypass emissions are calculated using a mass balance method, not using the flow and concentration values listed here.